

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/ms/school/2014/w2/1404

Dated: 14/11/14

FIRE SAFETY CERTIFICATE

Certified that the **North Delhi M.C.Pr.School** located at **Tulsi Nagar, Delhi -110035** comprised of Ground + 01 Upper Floor owned/ occupied by the North Delhi M.C.Pr.School have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and verified by the officers concerned of Fire Service on 24-09-2014 in the presence of Smt Mamta Gupta(Incharge) and that the building / premises is fit for the occupancy class "**Educational**" **Group B Sub Division B - 1** with effect from 14/11/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/11/14 at New Delhi.


(Santokh Singh)
Chief Fire Officer
PH-011-23414250

Copy to:

1. The Principal,
North Delhi M.C.Pr.School
Tulsi Nagar, Delhi -110035

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: North Delhi Mc Pr. School, Tulsi Nagar - 1
Index Loh, Delhi 110035
2. Type of Occupancy: Educational
3. Type of Case: New
4. Details of previous NOC: Letter No NIL
5. Fire Safety directives Letter No.: Doe circular 3298-3398 dated 1/3/2011
6. Date of inspection: 24/9/2014
7. Name of the Inspecting Officer: Uday Vir Singh, ADO (WP)
8. Name and designation of Officer
from the building side: Smt. Mamta Gupta
9. Year of Construction: 2012
10. Applicant's letter No.: DDE / KG2 / 2014 / 2875 dated 28/8/2014

No of students - 359.
Covered Area - 7260 sq
yard
No of class Room - 18

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	02	Provided	MR
	• Upper floors			✓
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	150cm	2 x 150cm	MR
	• Basements			✓
	c. Protection of exits			
	• Fire check door		NA	
	• Pressurization			
	d. No of continuous staircase	01	Provided	MR

	to terrace			
	e. Width Of Corridor	1.5 mtrs	Provided	MR
	f. Door Size	1 mtrs	Provided	MR
3.	Compartmentation			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	30 a/c per hour		
	• Upper floors	12 a/c per hour		
5.	Fire Extinguishers			
	• Total numbers	04	Provided	MR
	• Types	ABC	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor			
	• Length of hose reel hose	30 m		
	• Nozzle diameter	5 mm		
7.	Automatic fire detection and alarming system			
	• Type of detectors			
	• Location of Main Panel			
	• Location of Repeater Panel			
	• Alternate source of power			
	• Hooters' Location			
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	• Basements			
	• Upper Floor			

NA

NA

NA

NA

NA

NA

	<ul style="list-style-type: none"> • Sprinkler above false ceiling 				
11.	Internal Hydrants				
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 				
12.	Yard Hydrants				
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 				
13.	Pumping Arrangements				
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 				
14.	Captive water Storage for fire fighting				
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 				
15	Exit Signage				
16.	Provision of Lifts				
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 				

M/S

NA

NA

NA

NA

	Standby power supply				
18.	Refuge Area				
	➤ Total area				
	➤ Location				
19.	Fire control room				
	➤ Detector system panel				
	➤ Flow Switch Panel				
	➤ PA System Panel				
	➤ Battery backup				
	➤ Building Floor Plans				
20.	Special Fire Protection Systems for Protection of special Risks, if any;				

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

.....
NIL

Signature of the ~~Inspecting~~ Officer

Name

Uday Vir Singh

Designation

ADO (WP)

Signature of the Inspecting Officer

Name

Designation