

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110001**

E-mail:- [cfohq.dfire@nic.in](mailto:cfohq.dfire@nic.in)

Fax:- 011-23412593


No: F.6/DFS/MS/School/2014/ 52 /1426

Dated: 19 / 11 / 14

**FIRE SAFETY CERTIFICATE**

Certified that the building of **Shahid Captain Amit Verma Govt. Co-Ed. Sarvodaya Vidyalaya**, C-Block, Inderpuri, New Delhi -110012 having four blocks namely Old Block A, Old Block B, New Block A & New Block B. The Old Block A is comprised of ground floor only. The Old Block B, New Block A & New Block B are comprised of ground floor plus one upper floor was issued NOC by this department vide letter No.F.6/DFS/MS/School/2011/2889 dated 04.11.2011. The School building was re- inspected by the officer concerned of this department on 12.11.2014 in the presence of Sh. R.K. Sharma (Principal) and found that the school management (Govt. of NCT of Delhi) have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No- F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on .....19/11/14.....at New Delhi



(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:- 011-23414333

Copy to: -

1. The Principal,  
Shahid Captain Amit Verma Govt. Co-Ed. Sarvodaya Vidyalaya,  
C-Block, Inderpuri, New Delhi-110012.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

**INSPECTION REPORT**

1. Name & address of the building: Shahid Captain Amit Verma Govt. Co. Ed. Sarvodaya
2. Type of Occupancy: Educational (School) Vidyalaya, C-Block, Indrap
3. Type of Case: New Case/Renewal N.D-12
4. Details of Previous NOC: Letter No. F.6/DFS/MS/School/2011/2889 Dated 04.11.2011
5. Fire Safety directives letter No: —
6. Date of inspection: 12.11.2014
7. Name of Inspecting Officer: A.D.O P.S. Dahiya
8. Name and designation of officers  
From the building side: Sh. R.K. Sharma (Principal)
9. Year of Construction: 1965, 2001-02, 2010-11
10. Applicant's letter No.: 494/SCAY/IP/2014 dated 27.10.2014

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33   | Dir. Of Edu. Circular dt. 01.03.2011         | Provided at site                                  | Remarks MR/NMR                               |
|--------|---|--|---|--|
| 1.     | <b>Access to building</b>   |  |   |  |
|        | <ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>  | <p>Accessible</p> <p>—</p> <p>—</p>          | <p>09mtr</p> <p>290cms</p> <p>—</p>               | <p>MR</p> <p>MR</p> <p>—</p>                 |
| 2.     | <b>Number, Width, Type &amp; Arrangement of Exits</b>   |  |   |  |
|        | a. Number of staircases   |  |   |  |
|        | <ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>   | <p>Five</p> <p>—</p>                         | <p>Five</p> <p>—</p>                              | <p>MR</p> <p>No Basement</p>                 |
|        | b. Width of staircases  |  |   |  |
|        | <ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>  | <p>—</p> <p>—</p>                            | <p>150, 148, 150,<br/>145, 147cms</p> <p>—</p>    | <p>MR</p> <p>No Basement</p>                 |
|        | c. Protection of exits  |  |   |  |
|        | <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• pressurization</li> </ul>   | <p>—</p> <p>—</p>                            | <p>—</p> <p>—</p>                                 | <p>—</p> <p>—</p>                            |
|        | d. No. of continuous staircases to terrace  |  |   |  |
|        |   | —  | Three   | MR   |
|        | e. Width of Corridor  | —  | 210, 215, 175cms                                  | MR   |
|        | f. Door Size  | —  | 92 cms x 205 cms<br>94 cms x 210 cms              | MR, Old Case                                 |
| 3.     | <b>Compartmentation</b>   |  |   |  |
|        | <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul> | <p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p> | <p>—</p> <p>Sealed</p> <p>—</p> <p>—</p> <p>—</p> | <p>—</p> <p>—</p> <p>—</p> <p>—</p> <p>—</p> |
| 4.     | <b>Smoke Management System</b>  |  |   |  |
|        | <ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>   | 30 a/c per hour                              | —   | <p>No Basement</p> <p>MR</p>                 |
|        |   |  | Natural Ventilation                               | MR   |



M/9.

C-Block, Indraprastha,  
New Delhi-110012.

|            |   |          |          |                 |
|------------|---|----------|----------|-----------------|
|            | <ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>            | —        | —        | —               |
| <b>14.</b> | <b>Captive Water Storage for fire fighting</b>  |          |          |                 |
|            | <ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>                      | —        | —        | —               |
| <b>15.</b> | <b>Exit Signage.</b>  | Required | Provided | MR              |
| <b>16.</b> | <b>Provision of Lifts.</b>  |          |          |                 |
|            | <ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul> | —        | —        | No Lift<br>-do- |
| <b>17.</b> | <b>Standby power supply</b>   | —        | —        | —               |
| <b>18.</b> | <b>Refuge Area.</b>   |          |          |                 |
|            | <ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>  | —        | —        | —               |
| <b>19.</b> | <b>Fire Control Room</b>  |          |          |                 |
|            | <ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>                                  | —        | —        | —               |
| <b>20.</b> | <b>Special Fire Protection System for Protection of special Risks, if any:</b>  | —        | —        | —               |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/School/2011/2889 dated 04.11.2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Note:- The school building having four blocks namely Old Block A, Old Block B, New Block A & New Block B. The Old block A is comprised of Ground Floor only, The Old block B, New Block A & New Block B are comprised of Ground Floor plus One upper floor. The upper floors are served by five staircases having width 150cms, 148cms, 150cms, 145cms & 147cms respectively. The renewal of FSC is recommended please.



Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer

DO/SW.

Signature of Inspecting Officer

Name

Designation