

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/ school/2014/w2/1421

Dated: 19/11/2014

FIRE SAFETY CERTIFICATE

Certified that Vidya Bharti Public School, at Sector – 15, Rohini, Delhi 110085 comprised of Ground + Three Upper Floors owned/occupied by Vidya Bharti Public School has already been issued fire safety certificate Vide Letter No. F-6/DFS/MS/2011/1199 dated 14/06/2011. The premises was re-inspected by the officer from this department on dated 12/11/2014 in the presence of Mrs. Sovanika Pal (Principal) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition and there is no additional construction. The premises have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and building / premises is fit for occupancy under Education Class with effect from 19/11/2014 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 19/11/14 at New Delhi by


19/11
(Santokh Singh)
Chief Fire Office
Ph: 011-23414250

Copy to:

1. The Principal, Vidya Bharti Public School, at Sector – 15, Rohini, Delhi 110085
2. The Director of Education, Old Secretariat, Delhi

Received 02
copies
19/11/14

N/16

Vidya Bharti School, Sector-15, Rohini, Delhi-110085

INSPECTION REPORT

(G+3)

1. Name & address of the building : Vidya Bharti School, Sector-15, Rohini, Delhi-110085
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/2011/1199 dated 14/06/2011
5. Fire Safety directives letter No : Director of education 17/01/2005
6. Date of inspection : 12/11/2014
7. Name of the Inspecting Officers : DO (NW)
8. Name and designation of officers
from the building side : Mrs. Sovanika Pal (Principal)
9. 9. Year of Construction : 1992-93
10. 10. Applicant's letter No. : VBS/DFS/6927/14 dated 01/11/2014

Plot area:14165 sq mtr Covered area:24280 sq mtr No.'s of students:1520 No's of classrooms:- 68

	Minimum Standards on fire prevention and fire safety U/R 33	Director of education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 m	P	M/R ✓
	• Gate width	5 m	P	M/R ✓
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04	04	M/R ✓
	• Basements	--	--	--
	b. Width of staircases			
	• Upper Floors	1.5 m	1.5m x 4	M/R ✓
	• Basements	--	--	--
	c. Protection of exits			
	• Fire check door	--	--	--
	• Pressurization	--	--	--
	e. No. of continuous staircases to terrace	04	04	M/R ✓
	g. Width of Corridor	--	--	--
	h. Door Size	1 mtr	1 mtr	M/R ✓

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	N/A	N/A
		12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	22 ✓ ISI marked	22 12 ABC, 07 WCO2 & 03 CO2 Yes	M/R M/R M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	03 30 m 5 mm	P P P	M/R M/R M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8	MOEFA	R	P	M/R
9	Public Address System.	N/R	P	--
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	4'' 03 03	P P P	M/R M/R M/R
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	-- --	-- --	-- --

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	450 LPM	P	M/R
		40 m	P	M/R
		--	--	--
		--	--	--
		180 LPM	P	M/R
		40 m	P	M/R
		--	--	--
		--	--	--
		--	--	--
		--	--	--
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	--	--	--
		25000 ltr	P	M/R
		--	--	--
		--	--	--
		5000 ltr	P	M/R
15	Exit Signage.	R	P	M/R
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	--	--	--
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A



Vidya Bharti School, Sector-15, Rohini, Delhi-110085

	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F-6/DFS/MS/2011/1199 dated 14/06/2011** Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

DCFO (w2)

Designation

Surish
(DONW)

SS Tuli 7131 DCFO (w2)