

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2014/MO2/1481

Dated: 28/11/14

FIRE SAFETY CERTIFICATE

Certified that the Vikekanand International School at P.S-3,I.P.Extn.,Patparganj,Delhi - 92,owned/occupied by Vikekanand International School , comprising of ground plus three upper floors was granted FSC vide letter no.F6/DFS/MS/2011/2148 dated 26.08.2011.The School building was inspected by the officer concerned of this department on 27.09.2014 & 10.11.2014 in the presence of R.L.Ahuja,Manager of school building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building comprised of GF+FF+SF+TF is fit for occupancy Group B "Educational Building" with effect from ..28.11.14. for a period of three years, subject to conditions printed overleaf.


Issued on ...28/11/14..... at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Ph.011-23414333

To,
The Manager
Vikekanand International School
P.S-3,I.P.Extn.,Patparganj,Delhi -92,

Copy to:-
The Director of Education
Old Secretariat,Delhi -110054.



CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"

N/S

1. Name & address of the building : Vivekanand International School, P.S-3, I.P. Extn., Patpargang, Delhi-92.
2. Building is comprised of : Ground +3, upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC : F.6/DFS/ MS/2011/2148 Dated 02.09.2011
6. Fire Safety Circular No. : NBC Part IV
7. Date of Inspection : 27.09.2014 & 10.11.2014
8. Name of the Inspecting officers : DO Virendra Singh
9. Name and designation of Officer from the building side : Sh.R.L.Ahuja (Manager).
10. Year of Construction : 2003
11. Applicant's letter No : VIS/14/14 Dated 23.08.2014

NO.	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement	Provided at Site	Remark
1	Access to building	06 Mtrs.	20 Mtrs.	MR
	• Road width	4.5 M	6 M	MR
	• Gate width • Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	02 Nos.	2 Nos.	MR
	• Upper Floor	N/A	N/A	N/A
	• Basement			
	B. Width of Staircases	1.5 M	1.50 M each	MR
	• Upper Floor	N/A	N/A	N/A
	• Basement			
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
e. No. of continuous staircases to terrace	02No.	02 Nos.	MR	
g. Width of Corridor	1.5 M	1.7 M	MR	
h. Door Size	1.0 Mtrs	1.0 Mtrs	MR	
3	Compartmentation.	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• Upper floor			
5.	Fire Extinguishers	16 Nos.	20 Nos.	MR
	• Total numbers	ABC & Co2	ABC & Co2	MR
	• Types	ISI marked	ISI marked	MR
	• IS marking			


6	First-aid-Hose Reels.			
	Total numbers of each floor	02 Nos.	02 Nos.	MR
	• Length of hose reel hose	30 M	30 M	MR
	• Nozzle diameter	5 MM	5 MM	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 MM	100 MM	MR
	• Number of hydrants per floor	2 Nos.	2 Nos.	MR
	• Hose Box	2 Nos.	2 Nos.	MR
12	Yard Hydrants.	N/A	N/A	N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10000 Ltrs.	15000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire safety arrangements provided in the building were tested/ checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire Safety measures as required under the rules. The fire safety certificate issued vide letter no. F.6/DFS/MS/2011/2148 dated 02.09.2011, renewal under circular No. F.16/Estate/CC/FS/2011/3298to3398 dtd.01.03.2011 is recommended.

Submitted please.


 Signature of the Inspecting Officer
 Name: Virendra Singh
 Designation: DO(ED)