

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

Fax:- 011-23412593

E-mail ID: cfohq.dfire@nic.in

No. F6/DFS/MS/GH/2014/ ND2/1493

Dated 28/11/14

FIRE SAFETY CERTIFICATE

Certified that the M/s Fuji (A unit of K. House Restaurant Pvt. Ltd.), located at M-41/2, Speed Bird House, Middle Circle, Connaught Place, New Delhi building is comprised of **Basement + Ground + 3 floor (Office in Basement and Restaurant is running at Ground + Mezzanine floor only)** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 04-11-2014 in the presence of Sh. Ashelu (Manager) that the premises is fit for occupancy of class **Assembly Building Group-D of Sub-Division D-5** for ground floor + Mezzanine with effect from 28/11/14 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 28/11/14 at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. Dr. P.K. Sharma, Medical Officer of Health, Health Department, New Delhi Municipal Council Palika Kendra, New Delhi.
2. Sh. Ashelu (Manager) M/s Fuji (A unit of K. House Restaurant Pvt. Ltd.), located at M-41/2, Speed Bird House, Middle Circle, Connaught Place, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : M/s Fuji (A unit of K. House Restaurant Pvt. Ltd.), located at
 .. M-41/2, Speed Bird House, Middle Circle, Connaught Place, New
 .. Delhi.
2. Type of Occupancy : Assembly Building B + G + 3 floor (Office in Basement and
 .. Restaurant is running at Ground + Mezzanine floor)
3. Type of Case : Fresh
4. Details of previous NOC : NA
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 18/11/2014
- 7 Name of the Inspecting Officer : Sh. M.K. Sharma (ADO CC)
- 8 Name and designation of Officer
 from the building side : Mr. Ashelu Manager
- 9 Year of Construction : Old Heritage
10. Applicant's letter No. : No. D-348/MOH (Licensing)/SI-I dated 24/10/2014.

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	9Mtr. NA NA	16 Mtr. NA NA	MR NA NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	01	01	MR
	<ul style="list-style-type: none"> • Upper floors • Basements 	NA NA	NA NA	NA NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors 	1.50 mt. & 1 mt.	Mezz. floor 1.54 mt. 1.30 mt.	MR
	Basements	0.80 mt. & 1.25 mt.	0.80 mt. & 1.30 mt.	NA
	c..Protection of exits			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA

	<ul style="list-style-type: none"> • Pressurization 	NA	NA	NA
	d. No of continuous staircase to terrace			
	e. Width Of Corridor	01	01	MR
	f. Door Size	NA 02 mt	NA 02 mt	NA MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 ACPH	Mechanical	MR
	<ul style="list-style-type: none"> • Upper floors 	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	18	20	MR
	<ul style="list-style-type: none"> • Types 	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	<ul style="list-style-type: none"> • IS marking 	YES	Provided	MR
6	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	01	01	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 mt	30 mt	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	05 mm	05 mm	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	Required	Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler			
	<ul style="list-style-type: none"> • Basements 	Required	Provided	MR

		Required	Provided	MR
	Ground Upper Floor			
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down- comer	100mm	100mm	MR
	• Number of hydrants per floor	01	01	MR
	• Hose Box	01	01	MR
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	○ Ground Level			NA
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• auto Starting/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	○ Terrace level			NA
	• Discharge of pump	450 LPM	900 LPM & 280 LPM	MR
	• Head of the pump	30 mt	30 mt	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	NA	NA	NA
14	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	• Draw of connection	NA	NA	NA
	• Fire service inlet	NA	NA	NA
	• Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltrs	10,000 ltrs	MR

15	Exit Signage	Required	Provided	MR
16	Provision of Lifts	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> • Communication in lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> • Lift Signage 	NA	NA	NA
17	Standby power supply	NA	Provided	NA
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area 	NA	NA	NA
	<ul style="list-style-type: none"> • Location 	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> • Detector system panel 	NA	Provided	NA
	<ul style="list-style-type: none"> • Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • PA System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Batter backup 	NA	NA	NA
	<ul style="list-style-type: none"> • Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	ABC, Co ₂	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010, is recommended please.

Signature of the Inspecting Officer

M.K. Sharma

24/11/13

Name :- M.K. Sharma

Designation :- A. D.O. (CC)

Do (MR)

D.P.O. (ADD)