

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110 001

Fax:-011-23412593

E-mail ID: cfhq.dlfire@nic.in


No. F.6/DFS/MS/GH/2014/ 1402/1479

Dated: 27/11/14

FIRE SAFETY CERTIFICATE

Certified that the **Hotel Paras International** located at **5/25, W.E.A, Karol Bagh, New Delhi-110005** comprises of Basement, Ground floor + Four Upper floors, using basement as hall/storage, Ground floor as reception and offices, first, second & third floor each having eight guest rooms respectively (**Total 24 guest rooms**) and a pantry with staff room on terrace was granted NOC by this department vide letter No.F.6/DFS/MS/GH/2011/2675 dated 24-10-2011. The premises was re- inspected by the officer concerned of this department on 18-11-2014 in the presence of Mr. Jai Kumar (Manager) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, Sub-Division A-1 Guest House** for 24 guest rooms with effect from ~~27.11.14~~ 27.11.14 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.... 27.11.14at New Delhi by.



(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph-011-23414333

Copy to:-

1. The Joint Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi-110049 w.r.t. letter No. 39671/Joint C.P./Lic.(H) dated New Delhi 17-10-2014
2. Mr. Narender Arora (Owner) Hotel Paras International, 5/25, W.E.A, Karol Bagh, New Delhi-110005.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **www.dfs.delhigovt.nic.in**.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry"

INSPECTION REPORT

1. Name & address of the building : Hotel Paras International, 5/25, WEA, Karol Bagh, New Delhi-110005.
2. Type of Occupancy : Residential (Guest House) B+G+4 Floor total guest rooms-24
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/GH/2011/2675 dated 24/10/2011
5. Fire Safety directives letter No : N/A
6. Date of inspection : 18/11/2014
7. Name of Inspecting Officer : Dy. C.F.O Rajesh Panwar
8. Name and designation of officers
From the building side : Sh. Jai Kumar (Manager)
9. Year of Construction : Before 2008
10. Applicant's letter No. : 39671/Addl. C.P/Lic (H) dt New Delhi 17/10/2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site special area	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible NA NA	12 mtr NA NA	MR NA NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	One	One	MR
	• Basements	Two	Two	MR
	b. Width of staircases			
	• Upper Floor	125 cms	136 cms	MR
	• Basements	125 cms	116 cm, 157 cms	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	One	One	MR
	e. Width of Corridor	1.0 Mtr	1.60 Mtr	MR
	f. Door Size	1.0 Mtr.	86cm X 203 cm	MR, Old Case
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 ACPH 12 ACPH	Exhaust Fans are provided Natural Ventilation	MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	Two at each floor Water Co2, Co2 ISI marked	Provided Provided ISI marked	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One 30 m 5 mm	Provided Provided Provided	MR MR MR


7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power 	NA NA NA	NA NA NA	NA NA NA
	<ul style="list-style-type: none"> Hooters' Location 	Required	D.G set of 125 KVA	MR
		NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA NA NA NA NA NA NA NA NA NA 450 LPM 30 M Required NA	NA NA NA NA NA NA NA NA NA NA 450 LPM 30 M Provided NA	NA NA NA NA NA NA NA NA NA NA MR MR MR NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA	NA NA Provided NA	NA NA MR NA
		5000 Ltr	5000 Ltr	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA NA Required Required Required	NA NA Provided Provided Provided	NA NA MR MR MR

17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	Required	Provided	MR
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/GH/2011/2675 dated 24.10.2011 renewal under rule 35 of Delhi Fire Service Rules 2010, is recommended please.

Signature of Inspecting Officer



Name:- Rajesh Panwar

Designation:- Dy. C.F.O (NDZ)

Signature of Inspecting Officer

Name

Designation