

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. FB/DF/MS/SH/2014/W2/1440

Dated 24/11/2014

FIRE SAFETY CERTIFICATE

Certified that the **M/s. Shivam Foods, B-79, G.T. Karnal Road, Industrial Area, New Delhi – 110033** located on **Ground and First floor only of a Premises** comprised of **B + G + 2 upper floors** owned / occupied by **Mr. Vijay Kumar** have complied with the fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on **09.09.2014** in the presence of **Mr. Joshi (Manager)** and that the building/premises is fit for **Assembly** occupancy with effect from 24/11 2014 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire service rule, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 24/11/14 at New Delhi by


(Santokh Singh)
Chief Fire Officer
Delhi Fire Service
Phone -23414250

Copy to:

1. The Dy Health Officer, North Delhi Municipal Corporation, Health Department, Civil Zone, 16, Rajpur Road, Delhi 110054 for information
2. The authorized signatory, M/S Shivam Foods, B- 79, G.T. Karnal Road, Industrial Area, New Delhi 110033

INSPECTION REPORT

1. Name & address of the building : M/S Shivam Foods , B- 79, GTK Road, Ind. Area, Delhi
2. Type of Occupancy : Restaurant (Restaurant running on G + First floor with 135)
3. Type of Case : New Case (B + G + 2 upper floors storied building)
4. Details of previous NOC : nil
5. Fire Safety directives letter No : NBC Part IV
6. Date of inspection : 09/09/2014
7. Name of the Inspecting Officers : DCFO (WZ) & DO (NW)
8. Name and designation of officers
from the building side : Mr. Joshi (Manager)
9. Year of Construction : 2006
10. Applicant's letter No. : DHO/CLZ/2014/1080 Dated 14/08/2014 from MCD

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part IV Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6 m	P	M/R
		----	----	----
		----	----	----
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
		01 main staircase	02	Travel Distance meets the requirements with single staircase
	<ul style="list-style-type: none"> • Upper Floors • Basements 	01 emergency staircase	P	M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	1.5 mtr	1) 1.6 cm (2) 1.50 cm	M/R
		1.5 mtr	B/M closed affidavit enclosed	—
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	R	P	M/R
		--	--	--
	e. No. of continuous staircases to terrace	1	160 CM	M/R
	g. Width of Corridor	--	--	--

	h. Door Size	2 M X 2	P	M/R
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	R	P	M/R
		--	--	--
		--	--	--
		--	--	--
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	Exhaust fan provided P	M/R M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	10 ISI marked	16 04 ABC, 06 WCO ₂ & 06CO ₂ Yes	M/R M/R M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 30 m 5 mm	P P P	M/R M/R M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	R GF -- R --	Smoke P -- P --	M/R M/R -- M/R --
8	MOEFA	R	P	M/R
9	Public Address System.	R	P	M/R
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	R R --	P P --	M/R M/R --
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	04"	01	M/R

	<ul style="list-style-type: none"> Number of hydrants per floor 	01	01	M/R
	<ul style="list-style-type: none"> Hose Box 	01	01	M/R
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	01	P	M/R
	<ul style="list-style-type: none"> Hose Box 	01	P	M/R
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 			--
	➤ Discharge of main Pump	--	--	--
	➤ Head of Main pump	--	--	--
	➤ Number of main pumps	--	--	--
	➤ Jockey Pump out put	180 LPM	P	M/R
	➤ Jockey pump head	--	--	--
	➤ Standby Pump out put	--	--	--
	➤ Standby Pump Head	--	--	--
	➤ Auto Starting/ Manual stopping	--	--	--
	➤ Pump House Access	--	--	--
	<ul style="list-style-type: none"> Terrace level 			
	➤ Discharge of pump	900 LPM	P	M/R
	➤ Head of the pump	40 m	P	M/R
	➤ Power Supply	R	P	M/R
	➤ Auto Starting of pump	R	P	M/R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	--	--	--
	➤ Draw-off connection	R	P	M/R
	➤ Fire service inlet	R	P	M/R
	➤ Access to tank	--	--	--
	<ul style="list-style-type: none"> Overhead Tank capacity 	10,000 ltr	P	M/R
		R	P	M/R
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	--	--	--
	<ul style="list-style-type: none"> Communication In lift Car 	--	--	--
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	--	--	--

	• Lift Signage	--	--	--
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	R	P (GF)	M/R
	• Flow Switch Panel			
	• PA System Panel	R	P	M/R
	• Battery backup	R	P	M/R
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:	--	--	--

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

DCP (W2)

Signature of the Inspecting Officer

Name

Designation

Deep Singh
13/7/14
DO (W2)

