

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No. F6/DFS/MS/EH/2014/SZ/1469

Dated: 27/11/14

FIRE SAFETY CERTIFICATE

Certified that the M/S Sky Gourmet Catering Pvt. Ltd, IGI Airport Complex, New Delhi-110037, comprised of ground and first floor only, was granted NOC by this department vide letter No. F6/DFS/MS/EH/2011/3256, dated 29-11-11. The premises was re-inspected by the officer concerned of this department on 18-11-2014 in the presence of Sh. Shaik Mujab Ahmad.(Chief Engineer) and found that the said eating house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Eating House (Assembly Building) with effect from 27/11/2014 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/11/14 at New Delhi by.



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333

o/c
by

Copy to:-

Sh. Rohit Sawhney, Sky Gourmet Catering Pvt. Ltd,

IGI Airport Complex, New Delhi-110037.

Conditions for the validity of fire safety certificate are overleaf:-

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate on form J, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Sky Gourmet Catering Pvt. Ltd, IGI Airport Complex, New Delhi-110037.
2. Building comprises of : G+1.
3. Type of Occupancy : Eating House.
4. Type of Case : Renewal.
5. Details of Previous NOC :No.F6/DFS/MS/EH/2011/3256, dated 29.11.11.
6. Fire Safety direction letter No : Nil.
7. Date of Inspection : 18.11.14
8. Name of the Inspecting Officers: : Vedpal (ADO).
9. Name and designation of Officer from the building side : Sh. Shaik Mujab Ahmad.(Chief Engineer).
10. Year of Construction : 2007
11. Applicant's letter No :Letter dated 27.10.14.

S.No	Minimum Standards on fire prevention and fire safety as per Rule 33.	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	10m	MR
	Gate width	5m.	5m.	MR
	Width of internal road	8m	8m	MR
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases	.		
	Upper Floor	02nos.	03nos.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases	.		
	Upper Floor	1.25m	1.25m,1m,1.10m	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits	N.A.	N.A.	N.A.
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
g. Width of Corridor	N.A.	N.A.	N.A.	
h. Door Size	N.A.	N.A.	N.A.	
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	15 a/c per hour	Exhaust fan provided	MR

M/S Sky Gourmet Catering Pvt. Ltd, IGI Airport Complex, New Delhi-110037.

5.	Fire Extinguisher			
	Total numbers	18 nos.	41 nos.	MR
	Types	ABC&WCO ₂	ABC&WCO ₂	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	02nos.	02nos.	MR.
	Length of hose reel hose	30m	30m	MR.
	Nozzle diameter	5cm	5cm	MR.
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	Required	Provided	M R
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100mm	100mm	M R
	Number of hydrants per floor	02Nos.	02nos.	M R
	Hose Box	02Nos.	02nos.	M R
12	Yard Hydrants.			
	Total number of hydrants	04nos.	04nos.	MR
	Hose Box	04nos.	04nos.	MR
13	Pumping Arrangements.			
	➤ Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	900LPM	900LPM	MR
	➤ Head of Main Pump	40m	40m	MR
	➤ Number of main pumps	01no.	01no.	MR
	➤ Jockey pump out put	180 LPM	180LPM	MR
	➤ Jockey pump head	40 m	40m	MR
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	➤ Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.


14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	100000Liters	Provided	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.	Required	Provided	M R
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	Provided (50KVA DG Set)	M R
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Battery backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.6/DFS/MS/EH/2011/3256, dated 29.11.11, renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Signature of the Inspecting Officer

Name Vedpal

Designation ADO


19/11/14
