

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. *FG/DPS/MS/School/2014/ND2/1574*

Dated: *12/12/14*

FIRE SAFETY CERTIFICATE

Certified that the D.B.N Public School running at ground & first floor level of a building comprised of basement, ground plus one upper floor at Behind Shivani Apts., I.P. Extn., Delhi -92, owned/occupied by D.B.N Public School have complied with the fire prevention and fire safety requirements in accordance with the circular No.F.16/Estate/CC/FS/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and verified by the officers concerned of this department on 03.12.2014 in the presence of Head Master, of the school and that the ground & first floor of the building is fit for occupancy class 'B' "Educational Building" with effect from *12/12/14* for a period of three years, subject to conditions printed overleaf.

Issued on *12/12/14* at New Delhi by


(Dr.G.C.Misra)
Chief Fire Officer
Ph.011-23414333

To,
The Head Master
D.B.N Public School
Behind Shivani Apts., I.P. Extn.,
Delhi -92

Copy:-
The Dy. Director of Education (GNCT of Delhi)
D-Block, Anad Vihar, Delhi.

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction if any.
6. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The basement was found sealed during inspection by inspecting authorities. The same shall not used without the permission of this department and kept sealed as per the undertaking given by the head master of the school.

1. Name & address of the building: DBN Public School at Behind Shivani Apptt,
I.P. Extn., Delhi-92.
2. Building is comprised of : Basement Ground +1, upper floor.
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous NOC letter : Nil
6. Fire Safety direction letter No : F.16/Estate/CC/FS/2011/3298 to 3398
dated 1.3.11
7. Date of Inspection : 03.12.2014
8. Name of the Inspecting officers : DO Virendra Singh & ADO Suresh Singh
9. Name and designation of Officer:
from the building side : Head Master
10. Year of Construction : 2004
11. Applicant's letter No : dated 12.09.2014.

| NO. | Minimum Standards on fire prevention and fire safety U/R33 | Circular Requirement | Provided at Site | Remarks |
|-----|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------|------------------|---------|
| 1 | Access to building | | | |
| | <ul style="list-style-type: none"> Road width Gate width Width of internal road | 06 Mtrs. | 12 Mtrs. | M/R |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 2 | Number, Width, Type and Arrangement of Exits | | | |
| | a. Number of Staircases | | | |
| | <ul style="list-style-type: none"> Upper Floor ❖ Basement | 01 No. | 01 No. | MR |
| | | N/A | N/A | N/A |
| | B. Width of Staircases | | | |
| | <ul style="list-style-type: none"> Upper Floor ❖ Basement | 1.5 M | 1.5 M | MR |
| | | N/A | N/A | N/A |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> Fire check door Pressurization | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | e. No. of continuous staircases to terrace | N/A | N/A | N/A |
| | g. Width of Corridor | 01 No. | 01 No. | MR |
| | h. Door Size | 1.5 M | 2 M | MR |
| | | 1.0 Mtrs | 1.0 Mtrs | MR |
| 3 | Compartmentation. | | | |
| | <ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 4. | Smoke Management System. | | | |
| | <ul style="list-style-type: none"> Basement Upper floor | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types | 04 Nos. | 04 Nos. | MR |
| | | ABC & Co2 | ABC & Co2 | MR |
| | <ul style="list-style-type: none"> IS marking | ISI marked | ISI marked | MR |

❖ Basement is found sealed by providing wall .

| | | | | |
|----|-----------------------------------------------|-----|-----|-----|
| 6 | First-aid-Hose Reels. | | | |
| | Total numbers of each floor | N/A | N/A | N/A |
| | • Length of hose reel hose | N/A | N/A | N/A |
| | • Nozzle diameter | N/A | N/A | N/A |
| 7 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | N/A | N/A | N/A |
| | • Location of main panel | N/A | N/A | N/A |
| | • Location of repeater panel | N/A | N/A | N/A |
| | • Alternate source of power | N/A | N/A | N/A |
| | • Hooter's location | N/A | N/A | N/A |
| 8 | MOEFA | N/A | N/A | N/A |
| 9 | Public address System. | N/A | N/A | N/A |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | N/A | N/A | N/A |
| | • upper floor | N/A | N/A | N/A |
| | • sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | | | |
| | • size of riser/down-comer | N/A | N/A | N/A |
| | • Number of hydrants per floor | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 13 | Pumping Arrangements. | N/A | N/A | N/A |
| | • Ground Level | N/A | N/A | N/A |
| | ➤ Discharge of main Pump | N/A | N/A | N/A |
| | ➤ Head of Main Pump | N/A | N/A | N/A |
| | ➤ Number of main pumps | N/A | N/A | N/A |
| | ➤ Jockey pump out put | N/A | N/A | N/A |
| | ➤ Jockey pump head | N/A | N/A | N/A |
| | ➤ Standby pump out put | N/A | N/A | N/A |
| | ➤ Standby pump Head | N/A | N/A | N/A |
| | ➤ Auto Starting /Manual stopping | N/A | N/A | N/A |
| | ➤ Pump House Access | N/A | N/A | N/A |
| | • Terrace Level | | | |
| | ➤ Discharge of pump | N/A | N/A | N/A |
| | ➤ Head of the Pump | N/A | N/A | N/A |
| | ➤ Power supply | N/A | N/A | N/A |
| | ➤ Auto Starting of pump | N/A | N/A | N/A |
| 14 | Captive Water Storage for Fire Fighting. | N/A | N/A | N/A |
| | • Underground tank capacity | N/A | N/A | N/A |
| | ➤ Draw-off connection | N/A | N/A | N/A |
| | ➤ Fire service inlet | N/A | N/A | N/A |
| | ➤ Access to tank | N/A | N/A | N/A |
| | • Overhead Tank capacity | N/A | N/A | N/A |
| 15 | Exit Signage. | N/A | N/A | N/A |
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication in lift car | N/A | N/A | N/A |
| | • Firemen's grounding switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |

N/2

| | | | | |
|----|--------------------------------------------------------------------------|-----|-----|-----|
| 17 | Standby power supply | N/A | N/A | N/A |
| 18 | Refuge Area. | N/A | N/A | N/A |
| | • Total area | N/A | N/A | N/A |
| | • Location | N/A | N/A | N/A |
| 19 | Fire Control Room | N/A | N/A | N/A |
| | • Detector system panel | N/A | N/A | N/A |
| | • Flow switch panel | N/A | N/A | N/A |
| | • PA system panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N/A | N/A | N/A |

The fire extinguishers provided in the building were tested/ checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the circular no.F.16/Estate/CC/FS/2011/3298 to 3398 dated 01.03.11 is recommended to grant Fire Safety Certificate.

Singh
2.12.14

Signature of the Inspecting Officer
Name:-Suresh Singh
Designation:-ADO (Shah.)