

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No. F6/DFS/MS/Banquet/2014/W2/1510

Dated: 03/12/14

FIRE SAFETY CERTIFICATE

Certified that the **Lavanya Orchid Banquet Hall (M/s G.G. Enterprises)** located at **Plot No. 15, Nazafgarh Road, Shivaji Marg, New Delhi - 110015** in a building comprised of Basement + Ground + 2 Upper Floors owned/ occupied by **Lavanya Orchid Banquet Hall (M/s G.G. Enterprises)** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 07-11-2014 in the presence of Mr. Paramjit Kalra (General Manager) and found that the said building that the premises is fit for occupancy class "Assembly" Group D with effect from 03/12/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/12/14 at New Delhi by.


(Santokh Singh)
Chief Fire Officer,
Ph: 011 - 23414250.

Copy to:

1. The Authorised Signatory,
Lavanya Orchid Banquet Hall,
Plot No. 15, Nazafgarh Road, Shivaji Marg, New Delhi.
2. Dy. Health Officer, Karol Bagh Zone,
NDMC, Public Health Department,
Karol Bagh, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per Building Bye Laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/S

Re inspection to see the compliance of shortcomings communicated vide letter no. F6/DFS/MS/2014/1990 dated 26-08-2014.

INSPECTION REPORT

1. Name & address of the building: Lavanya Orchid Banquet Hall, 15 Main Road, Nazafgarh Road, Industrial Area, Moti Nagar, New Delhi – 110015.
2. Type of Occupancy : Assembly (Basement + Ground + 2 Upper Floor)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 07-11-2014
7. Name of the Inspecting Officer : Mukesh Verma, ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Paramjeet Kalra (GM)
9. Year of Construction : 2008
10. Applicant's letter No. : nil dated 05-10-2014

Plot Area = 669 m²
 Covered Area
 Basement=432m², GF=441 m²,
 FF= 441 m², SF=302 m²

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	5 m	On Main Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	2m & 1m	2m & 160 cm	MR
	• Basements	2m & 1m	2m & 160 cm	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Found Provided	MR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2m	Provided	MR
3.	Compartmentation			

	<ul style="list-style-type: none"> • Fire check door 	Required	Found Provided	MR
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	Required	Provided	MR
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	Required	Provided	MR
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	Provided	MR
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	12 nos.	Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC & CO2	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	1	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	Smoke & Heat	Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hooters' Location 	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> • Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	1	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	1	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NR	NR	NR
	<ul style="list-style-type: none"> • Hose Box 	NR	NR	NR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level 			
	<ul style="list-style-type: none"> • Discharge of main pump 	2280 lpm	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of main pump 	40 m	Provided	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps 	1	Provided	MR
	<ul style="list-style-type: none"> ➤ Jockey pump out put 	180 lpm	Provided	MR

➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump	40 m	Provided	MR
	2280 lpm	Found Provided	MR
	40 m	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
	900 lpm	Provided	MR
	40 m	Provided	MR
	Required	Provided	MR
	Required	Provided	MR
	14. Captive water Storage for fire fighting	50,000 litres	Provided
• Under ground tank capacity	Required	Provided	MR
➤ Draw of connection	Required	Provided	MR
➤ Fire service inlet	Required	Provided	MR
➤ Access to tank	10,000 litres	Found Provided	MR
• Overhead Tank capacity	Required	Provided	MR
15. Exit Signage			
16. Provision of Lifts			
➤ Pressurization of Lift Shaft	Required	Provided	MR
➤ Pressurization of lift lobby	Required	Provided	MR
➤ Communication in lift Car	Required	Provided	MR
➤ Fireman's Grounding Switch	Required	Provided	MR
➤ Lift Signage	Required	Provided	MR
17. Standby power supply	Required	Provided	MR
18. Refuge Area			
➤ Total area	NA	NA	NA
➤ Location	NA	NA	NA
19. Fire control room			
➤ Detector system panel	NA	NA	NA
➤ Flow Switch Panel	NA	NA	NA
➤ PA System Panel	NA	NA	NA
➤ Battery backup	NA	NA	NA
➤ Building Floor Plans	NA	NA	NA
20. Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers



Signature of the Inspecting Officer
Name
Designation

Mukesh Verma
10/11/14
MUKESH VERMA
ADO (MN)

Signature of the Inspecting Officer
Name
Designation

D. C. / F. C.

464/Dcf/622
13/11/14.

DO (West)

10/11

1/11/14