

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/EH/2014/ 52/1578

Dated: 15/12/14

FIRE SAFETY CERTIFICATE

Certified that the **McDonald's Family Restaurant**, 6A-6B, Sonia Cinema complex, Viaspuri, New Delhi 110018, is running at basement, ground floor and one upper floor only. The above restaurant was issued FSC vide Letter No. F6/DFS/MS/EH/2011/3122 dated 23.11.2011 owned/ occupied by M/S Connaught Plaza Restaurant Pvt. Ltd. The Restaurant building was re-inspected by the officers concerned of this department on 28.11.2014 in the presence of Sh. Jai Kishan (Shift Supervisor) and found that the M/S Connaught Plaza Restaurant Pvt. Ltd. have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant building/premises is fit for occupancy class Group D assembly building w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....15/12/14.....at New Delhi.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Manager,
Mc Donald's Family Restaurant,
6A-6B, Sonia Cinema complex,
Viaspuri, New Delhi 110018.

d/c San
15/12/14

INSPECTION REPORT

1. Name & address of the building: Mc Donald's Family Restaurant, 6A-6B, Sonia Cinema complex, Vikaspuri, New Delhi 110018.
2. Type of Occupancy : Group D (Assembly)
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/EH/2011/3122 dated 23.11.2011.
5. Fire Safety directives letter No : Nil.
6. Date of inspection : 28.11.2014
7. Name of Inspecting Officer : D.O. S.K. Tomar and A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Jai Kishan (Shift Supervisor)
9. Year of Construction : Before 2007
10. Applicant's letter No. : Nil dated 10.11.2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible — —	12 mtrs 180 cms 06 mtrs	M/R M/R, Being Old Case M/R
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Two Two	Two Two	M/R M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	— —	134 & 121 cms 120 & 112 cms	M/R, Being Old M/R, Being Old
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	— —	Provided —	M/R —
	d. No. of continuous staircases to terrace	—	One	—
	e. Width of Corridor	—	160 cms	—
	f. Door Size	—	100 cms	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	— N/A N/A N/A N/A	Provided Sealed N/A N/A N/A	M/R N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	—	Exhaust Fans Provided	M/R

Basement, Ground Plus One upper Floor (McDonald's Family Restaurant, 6A-6B, Sonia Cinema Complex, Vikaspuri, New Delhi 110018)

	<ul style="list-style-type: none"> Upper floors 	—	Natural Ventilation	M/R
5.	Fire Extinguishers (Restaurant at ^{Basement} Ground Floor only) ^{& 1st floor}			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	Three no's / floor ABC/CO2	Provided	M/R
			Provided	M/R
		ISI marked	ISI marked	M/R
6.	First-Aid Hose Reels (Restaurant at ^{Basement} Ground Floor only) ^{& 1st floor}			
	<ul style="list-style-type: none"> Total numbers on ground floor Length of hose reel hose Nozzle diameter 	one 30 mtrs 5 mm	Provided	M/R
			Provided	M/R
			Provided	M/R
7.	Automatic fire detection and alarming system (Restaurant at ^{Basement} Ground Floor only) ^{& 1st floor}			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Heat — — Required	Provided G. Floor — Provided Near exits	M/R M/R — M/R M/R
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	Required	Provided	M/R
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	Required Required N/A	Provided Provided N/A	M/R M/R N/A
11.	Internal Hydrants (Restaurant at ^{Basement} Ground Floor only) ^{& 1st floor}			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants Hose Box 	— — —	Provided Provided Provided	M/R M/R M/R
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	— —	— —	— —
13.	Pumping Arrangements (common with sonia PVR complex)			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping 	— — — — — — — — —	2250 LPM 80 mtrs 01 900 LPM 30 mtrs 2250 LPM & 450Lpm 88 & 30 mtrs Required	M/R M/R M/R M/R M/R M/R M/R M/R

Basement, Ground Plus One upper Floor (McDonald's Family Restaurant, 6A-6B, Sonia Cinema Complex, Vikaspuri, New Delhi 110018)

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	Provided	M/R
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14.	Captive Water Storage for fire fighting (common with sonia PVR complex)			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	120000 Ltrs	M/R
		—	Provided	M/R
		—	Provided	M/R
		—	Provided	M/R
		—	30000 ltrs	M/R
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	Required	Provided	M/R
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	Basement	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	Provided	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

N111

Basement, Ground Plus One upper Floor (McDonald's Family Restaurant, 6A-6B, Sonia Cinema Complex, Vikaspuri, New Delhi 110018)

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F6/DFS/MS/EH/2011/3122 dated 23.11.2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note: - The restaurant is in the PVR Cinema Complex, Vikaspuri and have common fire safety installations. The PVR Cinema was issued Fire Safety Certificate No. F6/DFS/MS/Cinema/2014/1201 dated 02.06.2014.

S.K. Tomar
#12/114

Signature of Inspecting Officer

Name:- S.K. Tomar

Designation:- Divisional Officer

Sandeep
04/12/14

Signature of Inspecting Officer

Name:- Sandeep Duggal

Designation:- Asstt. Divisional Officer