

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. FG/DF3)MS/EN/2014/W2/1575

Dated: 15/12/2014

FIRE SAFETY CERTIFICATE

Certified that M/S Yum! Restaurant (India) Pvt. Ltd. "KFC" at Shop no G-1/8 & G-10/ FG Plot no 15, District Centre, Mangalam Place, Sector 03, Rohini, Delhi located on Ground Floor of a premise comprised of Double Basement + Ground + Five Upper Floors owned / occupied by M/S Yum! Restaurant (India) Pvt. Ltd "KFC" have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 11/12/2014 in the presence of Sh. Jagjit Singh (Manager) and that the building / premises is fit for Assembly occupancy with effect from 15/12/2014 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 15/12/2014 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250

Copy to:

1. The Dy Health Officer, North Delhi Municipal Corporation, Health Department, (Rohini Zone) Sector-05, Rohini, Delhi-110085
2. The authorized signatory, M/S Yum! Restaurants (India) Pvt. Ltd, 258, Satyam Tower, Opposite Jwalaheri Market, Paschim Vihar, New Delhi- 110063

INSPECTION REPORT

Double Basement + Ground + Five Upper Floors

1. Name & address of the building : M/S Yum! Restaurant (India) Pvt. Ltd. KFC at shop no. G-1/8 & G-10, FG Plot No 15, District Centre, Mangalam Place Sec-3, Rohini
2. Type of Occupancy : Assembly
3. Type of Case : New Case (Restaurant running on Ground Floor only)
4. Details of previous NOC : --
5. Fire Safety directives letter No : BBL / NBC Part-IV
6. Date of inspection : 01/12/2014
7. Name of the Inspecting Officers : DO (NW)
8. Name and designation of officers
from the building side : Sh. Jagjit Singh (Manager)
9. Year of Construction : 2007
10. Applicant's letter No. : letter no nil dated 24/11/2014

S. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL & NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	M.R.
	• Gate width	Accessible	Accessible	M.R.
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors (on GF Only)	N.A	N.A	N.A
	• Basements	--	--	--
	b. Width of staircases			
	• Upper Floors	N.A	N.A	N.A
	• Basements	--	--	--
	c. Protection of exits			
	• Fire check door	--	--	--
	• Pressurization	--	--	--
	d. No. of continuous staircases to terrace			
		--	--	--
	e. Width of Corridor			
		--	--	--
	f. Door Size	1X2 m & one mtr	P	M.R.
3	Compartmentation.			
	➤ Fire check door	--	--	--
	➤ Sealing of electrical shafts	R	P	M.R.

	<ul style="list-style-type: none"> ➤ Fire Rating of shaft door ➤ Water Curtain ➤ Fire Dampers 	--	--	--
		N.A	N.A	N.A
		N.A	N.A	N.A
4	Smoke Management System.	Natural Ventilation		
	<ul style="list-style-type: none"> ➤ Basements ➤ Upper floors 	30 a/c per hour 12 a/c per hour	Provided with Mall Provided with Mall	M/R M/R
5	Fire Extinguishers			
	<ul style="list-style-type: none"> ➤ Total numbers ➤ Types ➤ IS marking 	One @ 300 m ² ISI marked	06 ABC/ CO2 yes	M.R. M.R. M.R.
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	R 30mm 5mm	P with Mall P P	M.R. M.R. M.R.
7	Automatic fire detection and alarming system.	Common with Mall		
	<ul style="list-style-type: none"> ➤ Type of detectors ➤ Location of Main Panel ➤ Location of Repeater Panel ➤ Alternate source of power ➤ Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8	MOEFA	R	P in restaurant	M.R
9	Public Address System.	N.A	P	M.R.
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> ➤ Basement ➤ Upper Floor ➤ Sprinkler above false ceiling 	N/A R N.A	N/A P in restaurant N.A	N/A M.R N.A
11	Internal Hydrants			
	<ul style="list-style-type: none"> ➤ Size of riser/down-comer ➤ Number of hydrants per floor ➤ Hose Box 	4'' 01 01	P with mall P P	M.R M.R. M.R.
12	Yard Hydrants.			
	<ul style="list-style-type: none"> ➤ Total number of hydrants ➤ Hose Box 	N/A N/A	P with mall N/A	N/A N/A

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		450 LPM	P <i>(Other than mall)</i>	M.R.
		40 m	P	M.R.
		R	P	M.R.
		R	P	M.R.
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		10,000 Ltr	10,000 ltr separate for restaurant <i>(other than mall)</i>	M.R.
15	Exit Signage.	R	P	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
17	Standby power supply	N.R	P with mall	M.R.
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A

19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	N.A	N.A	N.A
	<ul style="list-style-type: none"> • Flow Switch Panel 	N.A	N.A	N.A
	<ul style="list-style-type: none"> • PA System Panel 	N.A	N.A	N.A
	<ul style="list-style-type: none"> • Batter backup 	N.A	N.A	N.A
	<ul style="list-style-type: none"> • Building Floor Plans 	N.A	N.A	N.A
20	Special Fire Protection Systems for Protection of special Risks, if any:	---	No special risk seen at time of inspection	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

Delhi (NW)

Signature of the Inspecting Officer

Name

Designation

11/12/14
DO (NW)

