

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No.F.6/DFS/MS/School/2014/ 52/1583

Dated: 15/12/14

FIRE SAFETY CERTIFICATE

Certified that the building of **Sarvodaya Kanya Vidyalaya No.1**, Sagarpur, New Delhi - 110046, is having Four Blocks i.e. Three blocks (Old Block, Admn. Block & New Block) comprised of ground plus one upper floor and One Ground Floor block, was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/2011/School/3501 dated 14.12.2011 for three blocks i.e. Old Block, Admn. Block & Single Storey Block. The School building was re- inspected by the officer concerned of this department on 28.11.2014 in the presence of Smt. Nirupma Abhiyankar (Principal) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on..... 15/12/14 at New Delhi.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Principal,
Sarvodaya Kanya Vidyalaya No.1,
Sagarpur, New Delhi -110046.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya No.1, Sagarpur, New Delhi -110046.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/2011/School/3501 dated 14.12.2011.
5. Fire Safety directives letter No : N/A
6. Date of inspection : 28.11.2014
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Smt. Nirupma Abhiyankar (Principal)
9. Year of Construction : GF Block-1985, Old Block-2005, Admn. Block-2011 & New Block-2014
10. Applicant's letter No. : Letter No. SKV-1/SP-14/1297 dated 15.11.2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible — —	06 mtrs 4.7 & 4.3 mtrs. —	M/R — —
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	OB-03, AB- 02 & NB-02 No's	OB-03, AB- 02 & NB-02 No's	M/R
	b. Width of staircases	N/A	N/A	No basement
	<ul style="list-style-type: none"> • Upper Floor • Basements 	150 cms.	OB-192 & 142, AB-159 & 152 NB-182, 182 & 180 cms.	M/R
	c. Protection of exits	N/A	N/A	No basement
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	03No's	N/A
	e. Width of Corridor	150 cms	OB-153, AB-207 & NB- 172 cms.	M/R
	f. Door Size	N/A	95cms to 105 cms (double)	M/R, Old Case
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	No basement

Ground Plus One Upper Floor (03 Blocks i.e. Old Block, Admn. Block & New Block) and One Ground Floor Block {Sarvodaya Kanya Vidyalaya No.1, Sagarpur, New Delhi -110046}


	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
		N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.			
		No Lift		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A

Ground Plus One Upper Floor (03 Blocks i.e. Old Block, Admn. Block & New Block) and One Ground Floor Block {Sarvodaya Kanya Vidyalaya No.1, Sagarapur, New Delhi -110046}

20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A
-----	---	-----	-----	-----

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter number F.6/DFS/MS/2011/School/3501 dated 14.12.2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.



Sandeep
03/12/14

Signature of Inspecting Officer

Name:- Sandeep Duggal

Designation:- Asstt. Divisional Officer

Signature of Inspecting Officer

Name

Designation