

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/GH/2014/ 52 11563

Dated: 12/12/14

FIRE SAFETY CERTIFICATE

Certified that the Guest House **Living Room** located at A-9, Naraina Vihar, New Delhi-110028 is comprised of Basement, Service Floor, Ground Floor plus three upper floors, using basement as hall/storage, service floor as office & services, ground floor as kitchen, reception, office & 07 guest rooms, first, second & third floor each having 08 guest rooms & three rooms for personal use respectively (Total 31 guest rooms) and A.C plant and D.G set on terrace in tin shed was issued NOC by this department vide letter No.F.6/DFS/MS/GH/2011/2726 dated 28.10.2011 owned/ occupied by Mrs. Renu Mehrotra & Mrs. Chandra Khanna. The guest house building was re- inspected by the officers concerned of this department on 26.11.2014 in the presence of Sh. Dinesh Shrivastava (Manager Personal) and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class residential w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....12/12/14.....at New Delhi.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Joint Commissioner of Police (Lic.)
1st floor, P.S., Defence Colony, New Delhi.
(Re. No.39285/Joint C.P./Lic.(H), Dated 15.10.2014)
2. Mrs. Renu Mehrotra & Mrs. Chandra Khanna (Owner)
Guest House Living Room, A-9,
Naraina Vihar, New Delhi – 110028.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The basement shall be used strictly as per the provisions of the building bye laws.
7. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Basement, Service Floor, Ground Floor plus three upper floors.

N/7

INSPECTION REPORT

1. Name & address of the building : G.H Living Room, A-9, Naraina Vihar, N.D.
2. Type of Occupancy : Residential (Guest House)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F.6/DFS/MS/GH/2011/2726 Date 28.10.2011
5. Fire Safety directives letter No : _____
6. Date of inspection : 26.11.2014
7. Name of Inspecting Officer : D.O.S.K. Tomar & A.D.O P.S. Dahiya
8. Name and designation of officers
From the building side : Sh. Dinesh Shrivastava (Manager Personal)
9. Year of Construction : 2009-10
10. Applicant's letter No. : 39285/Joint C.P./LIC.(H) dated 15.10.2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	06 mtr	MR
	• Gate width	-	03 mtr	MR
	• Width of internal road	-	-	-
2.	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases			
	• Upper Floors	One	Two	MR
	• Basements	Two	- do -	MR
b.	Width of staircases			
	• Upper Floor	150 cms	150 cms, 110 cms	MR
	• Basements	- do -	150 cms, 110 cms	MR
c.	Protection of exits			
	• Fire check door	Required	Provided	MR
	• pressurization	-	-	-
d.	No. of continuous staircases to terrace			
		-	Two	MR
e.	Width of Corridor			
		-	142 cms	MR
f.	Door Size			
		-	90 cms x 220 cms	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	-	Sealed	MR
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4.	Smoke Management System			
	• Basements	30 a/c per hour	Exhaust Fans are Provided	MR
	• Upper floors		Natural Ventilation	MR

12 a/c per hour

5.	Fire Extinguishers			
	• Total numbers	Two at each Floor	Provided	MR
	• Types	CO ₂ , WCO ₂	- do -	MR
	• IS marking	ISI marked	ISI Marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	OR D.G. Set of 160 KVA 2200 KVA	MR
	• Hooters' Location	-	Near Staircase	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	- do -	- do -	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor	-	- do -	MR
	• Sprinkler above false ceiling	-	- do -	MR
11.	Internal Hydrants			
	• Size of riser/down-comer	-	100 M.M	MR
	• Number of hydrants per floor	-	Two	MR
	• Hose Box	-	One	MR
12.	Yard Hydrants			
	• Total number of hydrants	-	One	MR
	• Hose Box	-	- do -	MR
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-



N/9-

A-9, Naraina Vihar,
New Delhi - 110028

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
		900LPM	900LPM, 220LPM	MR
		30M	30M Each	MR
		Required	Provided	MR
		-	Both	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-	-	-
		-	Provided	-
		-	-	-
		15000 Ctr	15000 Ctr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts:			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	Provided	MR
		-	-	-
		Required	Provided	MR
		Required	-do-	MR
		-do-	-do-	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	-	-	-
		-	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	-	Provided	MR
		-	-	-
		-	Provided	MR
		-	-	-
		-	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	-	-	-

N/10

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/GH/2011/2726 dated 28.10.2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


31/11/14

Signature of Inspecting Officer

Name S.K. Tomar

Designation Divisional Officer


29/11/14

Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer