

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:-011-23412593

E-mail ID: cfohq.dfire@nic.in

No. F6/DFS/MS/EH/2014/ *N102/162*

Dated *22/12/14*

**FIRE SAFETY CERTIFICATE**

Certified that the M/S Nirula Restaurant ( A units of Nirula's Corner House Pvt. Ltd.) located at K-14, Connaught Circus, New Delhi comprises of Ground + Mezzanine floor owned/occupied by M/S Nirula Restaurant was granted NOC by this department vide letter No.F6/DFS/MS/EH/2011/1107 dated 06-06-2011. The premises was re-inspected by the officer concerned of this department on 28-11-2014 in the presence of Mr. N.K. Jain ( Manager) and found that the said restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group-D of Sub-Division D-5** with effect from ~~---22/12/2014~~ 22/12/2014 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..... *22/12/14* ..... at New Delhi by.

  
(Dr. G.C. Misra)  
Chief Fire Officer  
Delhi Fire Service  
Ph – 011-23414333

Copy to:-

1. Sh. Neeraj Bharati,  
Director, (Monitoring/Lic./Health ENF.) ,  
New Delhi Municipal Council, Palika Kendra, New Delhi.
2. Sh. N.K. Jain (Manager) M/S Nirula Restaurant ( A units of Nirula's Corner House Pvt. Ltd.) located at K-14, Connaught Circus, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry"

## INSPECTION REPORT

1. Name & address of the building : Nirula's Restaurant ( A unit of Nirulas Corner House Pvt. Ltd.  
... located at, K-14 ,Connaught Circus, New Delhi
2. Type of Occupancy : **Assembly Building (Ground + Mezzanine)**
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2011/1107 dated 06/06/2011
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 28/11/2014
- 7 Name of the Inspecting Officer : Sh. M.K. Sharma (ADO CC)
- 8 Name and designation of Officer  
from the building side : Sh. N.K. Jain (Manager)
- 9 Year of Construction : Old Heritage
10. Applicant's letter No. : No. D/349/MOH/Licensing/SI-1 dated 24/10/2014.

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Old Case Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	9Mtr. NA NA	16 mt NA NA	MR NA NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases (Mezzanine)	02	01 Old Case	MR
	<ul style="list-style-type: none"> <li>Upper floors</li> <li>Basements</li> </ul>	01 Mtr. Old case	01 Mtr.	MR
		NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper floors (Mezzanine)</li> <li>Basements</li> </ul>	1 mt	1 mt. Old case	MR
		NA	NA	NA
	c..Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	NA	NA	NA



	<ul style="list-style-type: none"> <li>• Pressurization</li> </ul>	NA	NA	NA
	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.25 mt	1.25 mt	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	NA	NA	NA
4	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	10	13	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC, CO <sub>2</sub> , Wco <sub>2</sub>	ABC, CO <sub>2</sub> , Wco <sub>2</sub>	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	YES	Provided	MR
6	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	01	01	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 mt	30 mt	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	05 mm	05 mm	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	NA	NA

15	Exit Signage	Required	Provided	MR
16	Provision of Lifts	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of lift lobby</li> <li>• Communication in lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> <li>• Total area</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location</li> </ul>	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> <li>• Detector system panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Flow Switch Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• PA System Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Batter backup</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Building Floor Plans</li> </ul>	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC, Co <sub>2</sub>	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no.

F6/DFS/MS/GH/2011/1107 dated 06/06/2011 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

*M.K. Sharma*

Name :- M.K. Sharma

Designation :- A. D.O. (CC)

*Do (CC)*  
*A. D.O.*  
*17/12/11*