

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax: 23412593, Tel: 011-23414333

No. F6/DFS/MS/IND./2014/ 52 / 1637

Dated: 23/12/14

FIRE SAFETY CERTIFICATE

Certified that **Evergreen Sweet House** located at **Plot No.Y-48, Okhla Industrial Area, Phase II, New Delhi-110025** comprised of **Basement, Stilt, Ground + 02 Upper Floors**. The premises was inspected by the officer concerned of this department on **11/12/2014** in the presence of **Mr. Pramod Kumar Sharma(Manager)** and found that the said building/premises have complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class **Industrial Building (G-2)** with effect from-----for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued -----at New Delhi by


23/12
(Dr. G.C. Misra)
Chief Fire Officer

etc
23/12/14
ADD (B&P)

Copy to:-

Sh. Pramod Kumar Sharma (Manager)
Evergreen Sweet House
Plot No.Y-48, Okhla Industrial Area
Phase II, New Delhi-110025

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Evergreen Sweet House, Plot No.- Y-48, Okhla Industrial Area,
Phase II, New Delhi-110025
2. Type of Occupancy : Industrial, G-2(Moderate Hazard)
3. Type of Case : New
4. Details of previous NOC : Nil
4. Fire Safety directives letter No : F-6/DFS/MS/BP/2013/104 Dated: 03.06.2013
5. Date of inspection : 11/12/2014
6. Name of the Inspecting Officers : ADO D.B.Mukherjee
7. Name and designation of officers from the building side: Mr. Pramod Sharma (Manager)
8. Year of Construction :2014
9. Applicant's letter No. : Nil, Dtd.: 02/12/2014

(Basement, Stilt, Ground + Two Upper Floors)

Sl. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	9 mtrs 5 mtrs N/A	Provided Provided N/A	MR MR N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 02	02 02	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	1.5 m 1.5 m	Provided 1.5 m each Provided 1.5 m each	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required N/A	Provided N/A	MR N/A
	e. No. of continuous staircases to terrace	One	02 Nos. Provided	MR
	g. Width of Corridor	1.5 mtrs.	Provided	MR
	h. Door Size	1 mtr.	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required Required N/A N/A N/A	Provided Provided N/A N/A N/A	MR MR N/A N/A N/A

4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour 12 a/c per hour	Basement Mechanical Extractor	MR
	<ul style="list-style-type: none"> Upper floors 		Exhaust Fan	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	ISI marked	20 ABC,Co2 Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m 5 mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke Ground Floor N/A Required Every Floor	Provided Provided N/A Provided Provided	MR MR N/A MR MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Required Required N/A	Provided Provided N/A	MR MR N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150 mm 01 01	Provided Provided Provided	MR MR MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	02 02	Provided Provided	MR MR

13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access 	2280 LPM	Provided	MR
		60 m	Provided	MR
		01	Provided	MR
		180 LPM	Provided	MR
		60 m	Provided	MR
		2280 LPM	Provided Diesel Driven	MR
		60 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Terrace level Discharge of pump Head of the pump Power Supply Auto Starting of pump 	900 LPM	Provided	MR
		40 mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank 	100000 Ltrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	20000 Ltrs.	Provided	MR
		Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.		120 KVA DG Set	
	<ul style="list-style-type: none"> Total Area Location 	N/A	N/A	N/A
		N/A	N/A	N/A

19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Flow Switch Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • PA System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Batter backup 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Building Floor Plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Extinguishers are provided for electric panel	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection. The fire safety directives issued vide letter no. F-6/DFS/MS/BP/2013/104 Dated 03.06.2013 has been complied. Keeping in view of substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010. Accordingly DFA is prepared for perusal and signature pl.

Signature
15/12/14

Signature of the Inspecting Officer
Name : D.B.Mukherjee
Designation :- Asstt. Div. Officer (BCP)

DO (Youth) on leave

Dy CPO (32) *[Signature]*
15/12/14