

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. f6/dfs/m/s/school/2014/w2/1676 Dated: 30/12/2014
FIRE SAFETY CERTIFICATE

Certified that Govt. Girls / Boys Sr. Sec. School, D-Block, Sultan Puri, Delhi comprised of 02 Blocks, One Block G + 1 & 2nd Blocks G.F only owned/occupied by Govt. Girls / Boys Sr. Sec. School have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 25/11/2013 in the presence of Sh. Shashi Varun (Principal) and that the building / premises is fit for occupancy of Educational building with effect from 30/12/2014 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 30/12/14 at New Delhi

29/12
(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, Govt. Girls / Boys Sr. Sec. School, D-Block, Sultan Puri, Delhi
2. The Director of Education, Old Secretariat, Delhi-110054.

INSPECTION REPORT

02 Blocks, 01 Block, G + 1, 2nd Block GF Only

1. Name & address of the building: Govt. Girls/Boys Sr. Sec. School, D-Block, Sultan Puri, Delhi.
2. Type of Occupancy : Education (ID. 1412088 Girls)
3. Type of Case : New Case (ID. 1412085 Boys)
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : Director of Education dated 01/03/2011
6. Date of inspection : 25/11/2014
7. Name of the Inspecting Officers : DO (NW)
8. Name and designation of officers
from the building side : Sh. Shashi Varun (Principal)
9. 9. Year of Construction : 1998
10. 10. Applicant's letter No. : 4797 dated 25/11/2014

Plot Area-3754 Sqm² Covered Area-3754 Sq m² Total Student-1131 Class Room-18

| | Minimum Standards on fire prevention and fire safety U/R 33 | Dir. Of Education Requirement | Provided at site | Remarks MR/NMR |
|---|---|-------------------------------|-------------------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | Accessible | Accessible | M.R ✓ |
| | • Gate width | -- | -- | -- |
| | • Width of internal road | -- | -- | -- |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 01 | 01 | M.R ✓ |
| | • Basements | -- | -- | -- |
| | b. Width of staircases | | | |
| | • Upper Floors | 1.5 m | 1.50 cm | M.R ✓ |
| | • Basements | -- | -- | -- |
| | c. Protection of exits | | | |
| | • Fire check door | -- | -- | -- |
| | • Pressurization | -- | -- | -- |
| | e. No. of continuous staircases to terrace | -- | -- | -- |
| | g. Width of Corridor | — | — | — |
| | h. Door Size | 1 M | All room provided double door | M.R ✓ |

| | | | | |
|----|---|------------------------------|---------------------|-------|
| 3 | Compartmentation. | | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| 4 | Smoke Management System. | | | |
| | <ul style="list-style-type: none"> • Basements • Upper floors | 30 a/c per hour | N.A | N.A |
| | | 12 a/c per hour | N.A | N.A |
| 5 | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers • Types • IS marking | One @300 m ² each | 20 | M.R ✓ |
| | | | 10- ABC / 10 Co2 | M.R ✓ |
| | | ISI marked | Yes | M.R ✓ |
| 6 | First-Aid Hose Reels. | | | |
| | <ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter | 30 m 5 mm | N.A | N.A |
| | | | N.A | N.A |
| | | | N.A | N.A |
| 7 | Automatic fire detection and alarming system. | | | |
| | <ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| 8 | MOEFA | N.A | N.A | N.A |
| 9 | Public Address System. | N.A | N.A | N.A |
| 10 | Automatic Sprinkler System. | | | |
| | <ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| 11 | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box | N.A | N.A | N.A |
| | | N.A | N.A | N.A |
| | | N.A | N.A | N.A |

| | | | | |
|----|---|-----|-----|-----|
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | N.A | N.A | N.A |
| | • Hose Box | N.A | N.A | N.A |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main Pump | -- | -- | -- |
| | ➤ Head of Main pump | -- | -- | -- |
| | ➤ Number of main pumps | -- | -- | -- |
| | ➤ Jockey Pump out put | -- | -- | -- |
| | ➤ Jockey pump head | -- | -- | -- |
| | ➤ Standby Pump out put | -- | -- | -- |
| | ➤ Standby Pump Head | -- | -- | -- |
| | ➤ Auto Starting/ Manual stopping | -- | -- | -- |
| | ➤ Pump House Access | -- | -- | -- |
| | • Terrace level | | | |
| | ➤ Discharge of pump | -- | -- | -- |
| | ➤ Head of the pump | -- | -- | -- |
| | ➤ Power Supply | -- | -- | -- |
| | ➤ Auto Starting of pump | -- | -- | -- |
| 14 | Captive Water Storage for fire fighting. | | | |
| | • Underground tank capacity | N.A | N.A | N.A |
| | ➤ Draw-off connection | N.A | N.A | N.A |
| | ➤ Fire service inlet | N.A | N.A | N.A |
| | ➤ Access to tank | N.A | N.A | N.A |
| | • Overhead Tank capacity | N.A | N.A | N.A |
| 15 | Exit Signage. | N.A | N.A | N.A |
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | N.A | N.A | N.A |
| | • Pressurization of Lift lobby | N.A | N.A | N.A |
| | • Communication In lift Car | N.A | N.A | N.A |
| | • Fireman's Grounding Switch | N.A | N.A | N.A |
| | • Lift Signage | N.A | N.A | N.A |
| 17 | Standby power supply | N.A | N.A | N.A |

Govt. Girls/Boys Sr. Sec. School, D-Block, Sultan Puri, Delhi

| | | | | |
|----|--|-----|-----|-----|
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N.A | N.A | N.A |
| | ➤ Location | N.A | N.A | N.A |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | N.A | N.A | N.A |
| | • Flow Switch Panel | N.A | N.A | N.A |
| | • PA System Panel | N.A | N.A | N.A |
| | • Batter backup | N.A | N.A | N.A |
| | • Building Floor Plans | N.A | N.A | N.A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | N.A | N.A | N.A |

Note: - General requirements for schools as per Director of Education circular dated

1. Escape route **Clear**
2. LPG cylinders in laboratories **Not used**
3. Electric wiring **concealed / conduit**
4. MCB and ELCB at Electric circuit **Provided**
5. Electric meter board **Below staircase & protected with metallic box**
6. Basement use as per BBL 1983 **N/A**
7. Emergency telephone no. board **Displayed**
8. Generator set **N/A**

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

DEFO (H2)

Signature of the Inspecting Officer

Name

Designation

[Signature]
4/12/14
DO (N/A)

803 / Ddfo (B)
22/12/14.