

014

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTER : DELHI FIRE SERVICE : NEW DELHI - 110001**

Fax:- 011-23412593

E-mail ID: cfhq.dlfire@nic.in


No. F6/DFS/MS/GH/2014/102/02

Dated 02/01/15

**FIRE SAFETY CERTIFICATE**

Certified that the M/s ZIZO unit of Olive Roots Pvt. Ltd. located at K-18 & K-22 Connaught Place, New Delhi building is comprised of Ground + Mezzanine + 2 floor (Restaurant is running at Ground + Mezzanine floor) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 19-12-2014 in the presence of Sh. Hemant (Manager) that the premises is fit for occupancy of class **Assembly Building Group-D of Sub-Division D-5 for restaurant at ground + mezzanine floor** with effect from ~~02/01/15~~ --- for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....02/01/15..... at New Delhi by.



(Dr. G.C. Misra)  
Chief Fire Officer  
Delhi Fire Service  
Ph - 011-23414333

Copy to:-

1. Assistant Commissioner (Restaurant Branch) Department of Excise, Entertainment and Luxurt Tax Govt. of NCT of Delhi, L & N Block, Vikas Bhawan, I.P.Estste, New Delhi.
2. M/s ZIZO unit of Olive Roots Pvt. Ltd.), located at K-18 & K-22 Connaught Place, NewDelhi

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

**INSPECTION REPORT**

1. Name & address of the building : M/s ZIZO unit of Olive Roots Pvt. Ltd.), located at K-18 & K-22 Connaught Place, New Delhi.  
 ....
2. Type of Occupancy : Assembly Building (Ground+ Mezzanine floor) G+ Mezz.+2 floor
3. Type of Case : Fresh
4. Details of previous NOC : NA
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 19/12/2014
- 7 Name of the Inspecting Officer : Sh. G.S Chauhan (DO/CD), Sh. M.K. Sharma (ADO CC)
- 8 Name and designation of Officer  
 from the building side : Sh. Hemant ( Manager)
- 9 Year of Construction : Old Heritage
10. Applicant's letter No. : No. F.2(52)/Ex/R/L-18/2014-15/478 dated 18/11/2014.

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/ NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9Mtr.	16 Mtr.	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	01	01	MR
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b.Width of staircases			
	• Upper floors	1.25 mt.	1.25 mt. & 0.83 mt.	MR
	Basements	Existing Old Bldg.	Existing Old Bldg.	
	c..Protection of exits	NA	NA	NA
	• Fire check door			
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
		01	01	MR

h  
Mank

N/2

	e. Width Of Corridor	NA	NA	NA
	f. Door Size	02 mt	02 mt	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	10	12	MR
	• Types	ABC, CO <sub>2</sub> , Wco <sub>2</sub>	ABC, CO <sub>2</sub> , Wco <sub>2</sub>	MR
	• IS marking	YES	Provided	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 mt	30 mt	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	Provided	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Requried	Provided	MR
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler			
	• Basements	NA	NA	NA
	• Ground Upper Floor	Requried	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			

h

Mena

	<ul style="list-style-type: none"> <li>• Size of riser/down- comer</li> </ul>	100mm	100mm	MR
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	01	01	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	01	01	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	NA	NA	NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>○ Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>• Discharge of main pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Head of main pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Number of main pumps</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Jockey pump out put</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Jockey pump head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Standby Pump out put</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Standby Pump Head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• auto Starting/Manual stopping</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Pump House Access</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>○ Terrace level</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Discharge of pump</li> </ul>	450 LPM	450 LPM 2Nos.	MR
	<ul style="list-style-type: none"> <li>• Head of the pump</li> </ul>	30 mt	30 mt	MR
	<ul style="list-style-type: none"> <li>• Power supply</li> </ul>	Requried	Provided	MR
	<ul style="list-style-type: none"> <li>• Auto starting of pump</li> </ul>	NA	NA	NA
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Draw of connection</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire service inlet</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Access to tank</li> </ul>	Requried	Provided	MR
	<ul style="list-style-type: none"> <li>• Overhead Tank capacity</li> </ul>	10,000 ltrs	10,000 ltrs	MR
15	Exit Signage	Requried	Provided	MR
16	Provision of Lifts	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Pressurization of lift lobby</li> </ul>	NA	NA	NA

h

mev

N14

	<ul style="list-style-type: none"> <li>• Communication in lift Car</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fireman's Grounding Switch</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Lift Signage</li> </ul>	NA	NA	NA
17	Standby power supply	NA	Provided	NA
18	Refuge Area			
	<ul style="list-style-type: none"> <li>• Total area</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location</li> </ul>	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> <li>• Detector system panel</li> </ul>	NA	Provided	NA
	<ul style="list-style-type: none"> <li>• Flow Switch Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• PA System Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Battery backup</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Building Floor Plans</li> </ul>	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	ABC, Co <sub>2</sub>	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010, is recommended please.

Signature of the Inspecting Officer

*G.S Chauhan*  
 23/12/14  
 Name :- G.S Chauhan  
 Designation :- DO (CD)

Signature of the Inspecting Officer

*M.K. Sharma*  
 23/12/14  
 Name :- M.K. Sharma  
 Designation :- ADO (CC)

