

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI- 110001


No. F6/DFS/MS/GH/2015/NDZ/ 11

Dated: 02/01/15

FIRE SAFETY CERTIFICATE

Certified that the Anuj Guest House running at ground, first & second floor of a building comprising of basement, ground plus three upper floors (basement lying vacant, ground floor reception and hall, first floor 12 nos guest rooms, second floor 12 nos guest rooms, third floor servant quarters) at A-10, Main Road Gazipur, Delhi-96 owner / occupied by M/s Anuj Guest House have complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 14.11.2014 in the presence of Sh Anuj, owner of the guest house and that the ground, first & second floor of building is fit for occupancy Group A "Guest House Building" for 24 guest rooms at first & second floor with effect from02/01/15..... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on02/01/15..... at New Delhi by


(Dr.G.C. Misra)
Chief Fire Officer
Ph.011-23414333

To,
The Joint Commissioner of Police (Lic.)
1st Floor, Police Station, Defence Colony,
New Delhi.

Copy to :-

- (1) Sh Mange Ram Sharma
A-10, Main Road Gazipur, Delhi-96
- (2) The Dy Health Officer
East Delhi Municipal Corporation, Health Department,
Shahdara (South) Zone, Karkardooma, Shahdara, Delhi

1. Name & address of the building : Anuj Guest House at Ground, 1st & 2nd floor, Plot no. A-10, Main Road Gazipur, Delhi -96.
2. Building Comprised of : Basement, ground plus three upper floors.
3. Type of Occupancy : Residential (Guest House)
4. Type of Case : New
5. Details of Previous FSC : Nil
6. Fire Safety directives No : As per NBC Part IV
7. Date of Inspection : 14.11.2014
8. Name of the Inspecting Officer : DO Virendra Singh & ADO Suresh Singh
9. Name of the designation of Officer
From the building side : Sh. Anuj (owner)
10. Year of Construction : 2009
11. Application / letter No : 35286-90/Joint.C.P./Lic.(H) dated 17.09.14

Sl.No.	Minimum Standards on fire prevention and fire safety U/R33	NBC Part IV Requirement	Provided at Site	Remarks
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 Mtrs.	12 Mtrs.	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> Upper Floor Basement 	01 No.	03 Nos.	MR
		02 Nos.	02 Nos.	MR
	B. Width of Staircases			
	<ul style="list-style-type: none"> Upper Floor Basement 	1.5 M	1.5 M, 1.25 M & 0.90 M	MR
		1.25 M	1.25 M	MR
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	e. No. of continuous staircases to terrace	2 Nos.	2 Nos. ^{2.1.25M} _{2.90M}	MR
	g. Width of Corridor	1.5 M	2.0 M	MR
	h. Door Size	1.0 M	1.0 M	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basement Upper floor 	N/A	N/A	N/A
		N/A	N/A	N/A
5.	Fire Extinguisher			
	<ul style="list-style-type: none"> Total numbers Types 	06 nos.	10 nos.	MR
		ABC & Co2	ABC & Co2	MR
	<ul style="list-style-type: none"> IS marking 	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	<ul style="list-style-type: none"> Total numbers of each floor Length of hose reel hose Nozzle diameter 	1 no.	1 no.	MR
		30 m	30 m	MR
		5 mm	5 mm	MR

7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	100 MM	MR
	• Number of hydrants per floor	N/A	1 No.	MR
	• Hose Box	N/A	1 No.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the Pump	40 Mtrs	40 Mtrs.	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltrs.	15,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

N/3

17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

S Singh
08-12-13

Signature of the Inspecting Officer

Name:-Suresh Singh

Designation: - ADO (Shad.)

DO/ED)

Submitted by alt a blance