

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**

**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**



No. F6/DFS/MS/SCHOOL/2014/ w2/ 1669

Dated: 26/12/14



**FIRE SAFETY CERTIFICATE**

Certified that the **Govt. Sarvodya Co-Ed. Sr. Sec. School** at **Hiran Kudna, New Delhi-110041 (School ID-1617006)** comprised of **Ground + One upper floor only** owned / occupied by **Govt. Sarvodya Co-Ed. Sr. Sec. School** have complied with the fire prevention and fire safety requirements in accordance with Director of Education **Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011** and verified by the officer concerned of Fire Service on **08.12.2014** in presence of **Sh. O.P. Saini (Vice Principal)** and that the building / premises is fit for occupancy class **Educational (Group-B)** with effect from .....26/12/14...for a period of 3 (three) years subject to conditions printed below.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
3. The trained fire- fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

**Issued on** 26/12/14 **at New Delhi by.**

  
(SANTOKH SINGH)  
CHIEF FIRE OFFICER  
Phone:-23414250 

**Copy to :-**

1. Executive Engineer, C.B.M. Div M-133 (N) (NCTD), Rama Road, Zakhira, Delhi-15.
2. Sh. O.P. Saini (Vice Principal), Govt. Sarvodya Co-Ed. Sr. Sec. School, Hiran Kudna, New Delhi-110041.
3. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054.

15  
**INSPECTION REPORT**

1. Name & address of the building: **Govt. Sarvodya Co-Ed. Sr. Sec. School,  
Hiran Kudna, New Delhi-110041. (ID-1617006)**
2. Type of Occupancy : **Educational**
3. Type of Case : **New**
4. Details of previous NOC : **Nil**
5. Fire Safety directives Letter No. : **No. F6/Estate/CC/Fire/Safety/2011/3298-3398  
Dated 01/03/2011**
6. Date of inspection : **08/12/2014**
7. Name of the Inspecting Officer : **A. K. Jaiswal**
8. Name and designation of Officer from the building side : **Sh. O.P. Saini (Vice-Principal)**
9. Year of Construction : **(GF-1985, G+1-2002)**

**10.** Applicant's letter No. :54(159)/CBMDM-133N/PWD/2013-14/1164 dated 30/10/2014

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE. Circ. Dated <u>01/03/2011</u> Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	2	MR
	• Basements	No basement	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50mtr.	90, 135, 145, 145cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.50 mtr	Provided	MR
	f. Door Size	1.00 mtr. $\times$ 2	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A

6.	First – Aid Hose Reels			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			

N/7

15	Exit Signage	N/A	N/A	N/A
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:-General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape route ..... Clear.....
2. LPG cylinders in laboratories ..... Nil.....
3. Electric wiring ... Conduit Wiring..... MCB and ELCB ..... ✓
- Electric circuit .....
4. Electric meter board ..... Not under the staircase.....
5. Basement use as per BBL 1983 ..... NA.....
6. Emergency telephone no. board ..... Displayed.....
7. Generator set ..... Nil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service rules 2010.

*Ashok Kumar Jaiswal*

8/12/14

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)

D.O. (Jw) *[Signature]*  
10/12

*D.O. (Jw) Pl. offer comments on no of doors in class rooms and strength is more than 45*