

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE [Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No: FG/DFS/MS/schal/2014/w2/1670

Dated: 26/12/14

FIRE SAFETY CERTIFICATE

Certified that the **Govt Sr. Sec. School, Anandwas, Delhi** comprised of one Blocks, Ground + 1 Upper Floor only owned and occupied by **Govt Sr. Sec. School, Anandwas, Delhi** have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and verified by the officers concerned of Fire Service on 18-11-2014 in the presence of **Smt Bhupander Kour (Principal)** and that the building / premises is fit for the occupancy class "**Educational**" **Group B Sub Division B - 1** with effect from 26/12/14... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on26/12/14... at New Delhi.


(Santokh Singh)
Chief Fire Officer
PH 011-23414250

Copy to:-

The Principal,
Govt Sr. Sec. School, Anandwas, Delhi .

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used as per building bye laws.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/4

FSC issued to C-F vide letter dt 14/10/11
presently - C+F-F

INSPECTION REPORT

1. Name & address of the building: Govt Girls Sr. Sec. School, Anandwas, Delhi
2. Type of Occupancy : Educational (One BL.Ground + 1 Upper Floor)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 18-11-2014
7. Name of the Inspecting Officer :Udai vir singh, ADO (WP)
8. Name and designation of Officer
from the building side :Smt. Bhupander Kour (Principal)
9. Year of Construction : 1975
10. Applicant's letter No. :DB(22)/PWD/M-33/2014-15/3310 dated 10/10/2014

No. of Students=1170
No. of class rooms=23
Plot area=4743 m ²
Covered area=1479m ²

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	150cm	2X150cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 mtr	105cm	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA

N/5

	<ul style="list-style-type: none"> Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements 	NA	NA	NA
	<ul style="list-style-type: none"> Upper floors 	NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	05nos.	Provided	MR
	<ul style="list-style-type: none"> Types 	ABC & CO ₂	Provided	MR
	<ul style="list-style-type: none"> IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	NA	NA	NA
	<ul style="list-style-type: none"> Length of hose reel hose 	NA	NA	NA
	<ul style="list-style-type: none"> Nozzle diameter 	NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down-comer 	NA	NA	NA
	<ul style="list-style-type: none"> Number of hydrants per floor 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level 			

	<ul style="list-style-type: none"> • Discharge of main pump 	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA

14/7

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings Nil as noted at serial numbers


Signature of the Inspecting Officer

Name Uday Vir Singh

Designation ASD/WP

Signature of the Inspecting Officer

Name

Designation