

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. RE/DFS/W/2014/W2/1492

Dated: 28/11/14

FIRE SAFETY CERTIFICATE

Certified that the **Hotel Waterfall** located at **A-3, Shubham Enclave, Paschim Vihar, New Delhi - 110063** comprised of Basement (Storage), Stilt (Parking), Ground Floor (Reception), First Floor (06 Rooms), Second Floor (06 Rooms) and Third Floor (06 Rooms) owned / occupied by Hotel Waterfall. The premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of Fire Service on 14/10/2014 in presence of Sh. Nitin (Manager) and that the Building / Premises is fit for occupancy class "Residential" Group A of Sub Division - A 1 with effect from 28/11/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in


Issued on 28/11/14..... at New Delhi by.



(Santokh Singh)

Chief Fire Officer.

Ph: 011 - 23414250



Copy to:

1. Joint commissioner of Police, Licensing Unit, First Floor, P.S. Defence Colony, w. r. t. Letter No. 35705-11/Joint CP/Lic.(H) dated 19/09/2014.
2. Sh. Kartikeya Vats, M/s Hotel Waterfall, A-3, Shubham Enclave, Paschim Vihar, New Delhi-110063.

N14
INSPECTION REPORT

1. Name & address of the building: Hotel Waterfall, A-3, Subham Enclave,
Paschim Vihar, New Delhi- 110063.
2. Type of Occupancy : Residential (Guest House)
3. Type of Case : New Basement + Stilt + Ground
Floor + Three Upper Floors
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : BBL-1983 ✓
6. Date of inspection : 14/10/2014
7. Name of the Inspecting Officer : D.O. (West) and A.D.O. (Jwala Puri)
8. Name and designation of Officer
from the building side : Sh. Nitin (Manager)
9. Year of Construction : 2008
10. Applicant's letter No. : - 35705-11/Joint CP/Lic.(H) dated 19/09/2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL-1983 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	18mtr	60mtr	MR
	• Gate width	NA	NA	NA
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	1	MR
	• Basements	1	2	MR
	b. Width of staircases			
	• Upper floors	1.25 Mtr. ✓	1.52 Mtr.	MR
	• Basements	1.25 Mtr. ✓	1.50 X 1 1.22 X 1	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1		
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.00mtr ✓	1.00 mtr.	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	Required ✓	Provided	MR
	• Upper floors	N/A	Provided	N/A
5.	Fire Extinguishers			

6.	First – Aid Hose Reels			
	• Total numbers on each floor	One at each floor	Provided ✓	MR
	• Length of hose reel hose	30 Mtr.	Provided ✓	MR
	• Nozzle diameter	5mm	Provided ✓	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	Smoke	NR
	• Location of Main Panel	N/A	GF	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	Provided ✓	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	NR	Provided ✓	NR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	Provided ✓	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	NR	150mm ✓	NR
	• Number of hydrants per floor	N/A	One at each floor ✓	NR
	• Hose Box	N/A	One at each floor ✓	NR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	900 Lit./ Min.	Provided ✓	MR
	➤ Head of the pump	40 Meter Head	Provided ✓	MR
	➤ Power supply	Required	Provided ✓	MR
	➤ Auto starting of pump	Required	Provided ✓	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NR	25,000 Ltr ✓	NR

N/16

15	Exit Signage	Required	Provided	M/R
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided ✓	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Accordingly FSC in Form 'H' is put up for signature please.

Note! Reference BBL clause 16.3.5

Ashok Kumar Jaiswal

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)

Signature of the Inspecting Officer

Name : Sunil Chawdhary

Designation : D.O. (West)