

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**


NO. F6/DFS/MS/School/2014/ SZ/ 1630

DATED: 23/12/14

**FIRE SAFETY CERTIFICATE**

Certified that the Lakshay Education Welfare and Charitable Society, Plot No.1, Sector-11, Dwarka, New Delhi, comprised of ground plus one upper floor was granted NOC by this department vide letter No.F6/ DFS/MS/2008/67 dated 10.1.2008. The school building was re-inspected by the officer concerned of this department on 10.12.2014 in the presence of Sh. Daven Khular (Chairperson) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi Letter No: Estate/CC/Fire Safety/2011/3298 Dtd. 01.03.2011 and that the school building is fit for occupancy of class B "Educational Building" for ground plus two upper floors with effect from 23/12/14 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed overleaf.

Issued on 23/12/14..... at New Delhi by



(Dr. GC Misra)  
Chief Fire Officer  
Ph.011-23414333

**Copy to:**

- 1 Dy. Director, (Education) GNCT of Delhi, Old Secretariat, New Delhi-110054.
- 2 Chairman, Lakshay Education welfare and charitable Society, 289, Satya Niketan, New Delhi-110021.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per the building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

## INSPECTION REPORT

1	Name & address of the building	Lakshay Education Welfare and Charitable Society, Plot No.-1, Sector-11, Dwarka, New Delhi.	
2	Type of Occupancy	Educational Building "B"	
3	Type of case	Renewal	
4	Details of previous NOC	F6/DFS/MS/2008/67 dated 10.1.2008	
5	Fire safety directives letter No	Directorate of Education: F/16/Estate/CC/fire Safety/2011/3298-3398, Dated 1.3.2011	
6	Date of inspection	12.12.2014	
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Sh. Daven Khullar (Chairperson)	
9	Year of construction	2008	
10	Applicant's letter No.	Nil Dated.3.11.2014	Ground+1 upper floor

**Management has constructed one more upper floor ( Now G+2 upper floors)**

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
<b>1</b>	<b>Access to building</b>			
	1) Road width	Accessible	30 Mtrs.	MR
	2) Gate width	Accessible	4.2 Mtrs.	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5 Mtrs. 1 Mtr.	1.5 Mtrs. & 1 mtr.	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	1 No.	MR
	e. Width of corridor	1.25 Mtrs.	2.06 Mtrs.	MR
	f. Door size	1 Mtr.	1 Mtr.	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement		N/A	N/A
	upper floors	12 a/c charge	Natural Vent.	MR
<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	One No. Co2 OR ABC for every 300 Sq.Mtrs.	6 Nos.	MR
	Types	ISI Marked	Co2 & ABC	MR
	ISI marking	ISI Marked	Provided	MR

<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	1 No.	1 No. each floor	MR
	Length of Hose reel hose	30 Mtrs.	30 Mtrs.	MR
	Nozzle Diameter	5 mm	5 mm	MR
<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
<b>8</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9</b>	<b>Public Address System.</b>	Old Case	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
<b>12</b>	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	450 Lpm.	450 LPM	MR
	b. head of the pump	40 Mtrs.	40 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	MR
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5000 Ltrs.	5000 Ltrs.	MR
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16</b>	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	ABC		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety required under the rules , renewal of FSC issued vided letter no. DFS/MS/2008/67 dated 10.1.2008 for Ground plus one upper floor is recommended for ground plus two upper floors under rule 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval and signature please.

*S.P. Bhardwaj*  
12/12/14

Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)