

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

Fax: 23412593, Tel: 011-23414333

NO.F6/ DFS/ MS/School/2014/ 52/1634


Dated: 23/12/14

**FIRE SAFETY CERTIFICATE**

Certified that, Nagar Nigam Primary Bal Vidyalaya, Located at Janta Grih-II D.D.A. Flat Kalkaji, New Delhi-110019, comprised of Ground Floor Only. owned/occupied by S.D.M.C. was issued FSC vide letter No F6/DFS/Ms/2011/2909 dated 08/11/2011 was re- inspected by the officer concerned of this department on 15/12/2014 in the presence of Mrs. Kiran (Incharge) and found that the School have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 and that the school building is fit for occupancy class "Educational"(School) with effect from the date of issue of this certificate for a period of three years, subject to compliance of the below mentioned conditions.

Issued on ~~23/12/14~~----- at New Delhi by.

  
(Dr. G.C. Misra)  
Chief Fire Officer

  
23/12/14  
ADD/BCP

Copy to: -

The Principal,  
S.D.M.C. Primary School,  
Janta Grih-II,D.D.A.Flat Kalkaji,  
New Delhi-110019

**Conditions for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building :Nagar Nigam Primary Bal vidyalaya, Janta Girah-II,  
D.D.A. Flat kalkaji,New Delhi-110019
2. Type of Occupancy : Educational (School)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2011/2909 dated 08/11/2011
5. Fire Safety directives letter No : F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01-03-2011.
6. Date of inspection : 15/12/2014
7. Name of the Inspecting Officers : ADO D.B.Mukherjee
8. Name and designation of officers  
from the building side : Mrs. Kiran (incharge)
9. Year of Construction : 1973
10. Applicant's letter No. : Nil dated: 28/11/2014

(Building is comprised of Ground Floor Only)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Directorate of Education Circular Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Required	Provided	MR
	• Gate width	Required	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1m	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A



	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 a/c per hour	N/A	N/A
		12 a/c per hour	N/A	N/A
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	Required	05 nos	MR
		ABC,CO <sub>2</sub>	Provided	MR
		Required	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	<b>MOEFA</b>			
		N/A	N/A	N/A
9	<b>Public Address System.</b>			
		N/A	N/A	N/A
10	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
13	<b>Pumping Arrangements</b>			

	<ul style="list-style-type: none"> <li>• Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
14	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
15	<b>Exit Signage.</b>	N/A	N/A	N/A
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	N/A	N/A
19	<b>Fire Control Room</b>			

2/9

	<ul style="list-style-type: none"> <li>• Detector System Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Flow Switch Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• PA System Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Batter backup</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the school were test checked and found functional at the time of inspection.


Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules FSC issued by this department vide letter No.F.6/DFS/MS/2011/2909 dated 08/11/2011, renewal of Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

 17/12/14

Signature of the Inspecting Officer  
Name (D.B.Mukherjee)  
Designation :- Assistant Divisional Officer

Do (sonu) on leave

Do (fo) (sr)

  
17/12/14