

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax: 23412593, Tel: 011-23414333

No.F6/MS/DFS/School/2014/ 52/1558

Dated:-----11/12/14

FIRE SAFETY CERTIFICATE


Certified that Tagore International School, Paschimi Marg, Vasant Vihar, New Delhi-110057 comprised of four interconnected blocks (Two blocks are ground + two upper floor & Two blocks are ground + three upper floor), owned/occupied by School Management was issued NOC vide letter no.F6/DFS/MS/08/3523 dated 23/12/2008 by this department. The school building was inspected by the officer concerned of this department on 27/11/2014 in the presence of Mr. Harwinder Walia (Admin) and found that the School building have deemed complied with the fire prevention and fire safety requirements and that the school building is fit for occupancy class "Educational" (School) with effect from the date of issue..... of this certificate for a period of three years, subject to compliance of the below mentioned conditions.

Issued on ---11/12/14--- at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer

Copy to: -

The Administrative Officer,
Tagore International School,
Paschimi Marg, Vasant Vihar,
New Delhi-110057


10/12/14
ADD (B&P)

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Tagore international School, Paschimi Marg, Vasant Vihar ,
New Delhi-110057
2. Type of Occupancy : Educational (School)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/08/3523 dated 23/12/08
5. Fire Safety directives letter no. : Nil.
6. Date of inspection : 27/11/2014
7. Name of the Inspecting Officers : ADO D.B. Mukherjee
8. Name and designation of officers
from the building side : Mr. Harwinder Walia (Admn)
9. Year of Construction :
10. Applicant's letter No. : Nil dated 27/08/2014

(The school is running in four blocks and all blocks are interconnected with each other. Two blocks are ground + two upper floor & Two blocks are ground + three upper floor) (Old Case)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Directorate of Education Circular Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Required	Provided	MR
	• Gate width	Required	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
a. Number of staircases				
• Upper Floors	02		05nos	MR
• Basements	N/A		N/A	N/A
b. Width of staircases				
• Upper Floors	1.50m		1.18m, 1.20m, 0.92m, 1.25m, 1.20m	MR
• Basements	N/A		N/A	N/A
c. Protection of exits				
• Fire check door	N/A		N/A	N/A
• Pressurization	N/A		N/A	N/A
e. No. of continuous staircases to terrace	03		03	MR
g. Width of Corridor	1.5mtr		Provided	MR
h. Door Size	1mtr		Provided	MR

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Dampers 	N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	Required	30 nos.	MR
	<ul style="list-style-type: none"> • Types 	ABC,CO ₂	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	Required	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	01 in each floor and each block.	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	Required	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	Required	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hooters' Location 	N/A	N/A	N/A
8	MOEFA			
		N/A	N/A	N/A
9	Public Address System.			
		N/A	N/A	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	Required	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	Required	Provided	MR

12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided 4nos	MR
	➤ Head of the pump	40m	43m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	20,000ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A




18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the school were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/08/3523 dated 23/12/2008, renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for perusal and signature pl.

Do (copy)


8/12/14


11/12/14

Signature of the Inspecting Officer
Name: (D.B.Mukherjee)
Designation :- Assistant Divisional Officer

