

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No. F610F/MS/2014/1496

Dated: 28/11/14

FIRE SAFETY CERTIFICATE

Certified that The Sky Bar (A Unit of Big Shots Hospitality) located at 2nd & 3rd Floor, A - 7, Vishal Enclave, Rajouri Garden, New Delhi - 110027 in a building comprised of Basement + Ground + 3 Upper Floors owned/ occupied by The Sky Bar (A Unit of Big Shots Hospitality) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 12-11-2014 in the presence of Mr. Manpreet Singh Talwar (Partner) and found that the said building that the premises is fit for occupancy class " Assembly" Group D with effect from 28/11/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28/11/14 at New Delhi by.

Copy to:

1. Sh. Manpreet Singh Talwar,
2nd & 3rd Floor, A - 7, Vishal Enclave,
Rajouri Garden, New Delhi - 110027.
2. Dy. Health Officer, West Zone,
SDMC, Public Health Department,
Vishal Enclave, New Delhi.


28/11
(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in


26/11

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per Building Bye Laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

Basement = Storage ✓ Area
 Ground floor = Vacant ✓ 2300 sqm
 1st floor = Sweet Shop ✓
 2nd floor = Restaurant ✓

INSPECTION REPORT

1. Name & address of the building: The Sky Bar (A Unit of Big Shots Hospitality).
 2nd & 3rd Floor, A – 7, Vishal Enclave, Rajouri Garden, New Delhi – 110027.
2. Type of Occupancy : Assembly (Basement + Ground + 3 Upper Floors)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 12-11-2014
7. Name of the Inspecting Officer : Sunil Chawdhary DO (West) & Mukesh Verma ADO (MN)
8. Name and designation of Officer
 from the building side : Sh. Manpreet Singh Talwar (Partner)
9. Year of Construction : 2006 *electricity, Jal board etc. bill ends*
10. Applicant's letter No. : D2269/DHO/WZ/2014 dated 09-10-2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	9 m NA NA	Provided On Main Road NA	MR NA NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5m & 1m	Provided	MR
	• Basements	1.5m & 1m	Provided	MR
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	NR	NR	NR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2m	Provided	MR
3.	Compartmentation			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR

	<ul style="list-style-type: none"> Water Curtain Fire Dampers 	NR	NR	NR
4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hr	Provided	MR
		12 a/c per hr	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	6 nos. ABC & CO2 ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	1	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Heat	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NR	NR	NR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required	provided	MR
		NR	Provided	MR
		NR	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm	Provided	MR
		1	Provided	MR
		1	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NR	NR	NR
		NR	NR	NR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping Pump House Access Terrace level 	2280 lpm	Provided	MR
		40 m	Provided	MR
		1	Provided	MR
		180 lpm	Provided	MR
		40 m	Provided	MR
		2280 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		900 lpm	Provided	MR
		40 m	Provided	MR

	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	50,000 litres	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

Signature of the Inspecting Officer
 Name **MUKESH VERMA**
 Designation **ADD (MN)**

Signature of the Inspecting Officer
 Name
 Designation