

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. f6/dfs/ms/EH/2014/w2/1649

Dated: 24/12/14

FIRE SAFETY CERTIFICATE

Certified that the YUM Restaurant (India) Private Limited, KFC, Ground Floor (Shop No. 2,3,4,5) & First Floor (Shop No. 102,103,104,105), ARSS Felix The Mall, Plot No. 40, Block-A, Community Centre, Paschim Vihar, New Delhi – 63 owned / occupied by YUM Restaurant (India) Private Limited, KFC have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by officers concerned of Fire Service on dated 31/10/2014 in the presence of Sh. B.N.S. Chauhan (Project Department) and that the premises is fit for occupancy class "Assembly" (Group D) with effect from 24/12/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the Fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The means of escape shall be kept unlocked & free of obstruction for unhindered escape of occupants in case of an emergency.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

Issued on 24/12/14 at New Delhi by.

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph-23414250

Copy to: -

1. Dy. Health Officer (Rohini Zone), North Delhi Municipal Corporation, Sector-5, Rohini, New Delhi-110085.
2. Chandan Tiwari, YUM Restaurant (India) Private Limited, KFC, Ground Floor (Shop No. 2,3,4,5) & First Floor (Shop No. 102,103,104,105), ARSS Felix The Mall, Plot No. 40, Block-A Community Centre, Paschim Vihar, new Delhi-63.

## INSPECTION REPORT

1. Name & address of the building: YUM Restaurant (India) Private Limited, **KFC**, Ground Floor (Shop No. 2,3,4,5) & First Floor (Shop No. 102,103,104,105), ARSS Felix The Mall, Plot No. 40, Block-A, Community Centre, Paschim Vihar, New Delhi – 63.
2. Type of Occupancy : **Assembly**
3. Type of Case : **New**
4. Details of previous NOC : **NIL ( FSC issued to the Mall vide letter No.F6/DFS/MS/2014/WZ/489 dated 17/04/2014)**
5. Fire Safety directives Letter No. : **Nil**
6. Date of inspection : **31/10/2014**
7. Name of the Inspecting Officer : **A.K. Jaiswal & Sunil Chawdhary**
8. Name and designation of Officer  
from the building side : **Sh. B.N.S. Chauhan (Project Department)**
9. Year of Construction : **2013**
10. Applicant's letter No. : **DHO/RZ/2013/1013 Dated 25/09/2014**

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	1 (Internal) 2 (Mall)	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 Mtr. & 1.00 Mtr. (Emergency Door)	1.50 Mtr.x2 (Mall) & 1.20 Mtr (Internal Stair)	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	2Mtr. x1, 1Mtr. x1 (Emergency Door)	2.00Mtr. x1, 1.70Mtr. x1	MR
3.	Compartmentation			
	• Fire check door	N/A Required	N/A Provided	N/A MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided by the Mall	MR
	• Length of hose reel hose	30 Mtr.	Provided by the Mall	MR
	• Nozzle diameter	5 mm	Provided by the Mall	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Required	Provided	MR
	• Location of Main Panel	Required	Provided by the Mall	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down-comer	Required	Provided by the Mall	MR
	• Number of hydrants per floor	Required	Provided by the Mall	MR
	• Hose Box	Required	Provided by the Mall	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements <b>Provided In the Mall</b>			
	• Ground Level			
	➤ Discharge of main pump	N/A	Provided by the mall	N/R
	➤ Head of main pump	N/A	Provided by the mall	N/R
	➤ Number of main pumps	N/A	Provided by the mall	N/R
	➤ Jockey pump out put	N/A	Provided by the mall	N/R
	➤ Jockey pump head	N/A	Provided by the mall	N/R
	➤ Standby Pump out put	N/A	Provided by the mall	N/R
	➤ Standby Pump Head	N/A	Provided by the mall	N/R
	➤ Auto Staring/Manual stopping	N/A	Provided by the mall	N/R
	➤ Pump House Access	N/A	Provided by the mall	N/R
	• Terrace level			
	➤ Discharge of pump	900 LPM	Provided by the mall	N/R
	➤ Head of the pump	40 MTR	Provided by the mall	N/R
	➤ Power supply	Required	Provided by the mall	N/R
	➤ Auto starting of pump	Required	Provided by the mall	N/R
14.	Captive water Storage for fire fighting			

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service rules 2010.

*Note: G. floor & 1st floor are interconnected through internal staircase with two doors at each floor*

*Ak Jaiswal*  
Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Name : Sunil Chawdhary

Designation : A.D.O. (Jwala Puri)

Designation : D.O. (West)