

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110 001

No. F 6/DFS/MS/Petl/2015/S2/70

Dated: 14/01/15

FIRE SAFETY CERTIFICATE

Certified that M/S Bansawal Service Station(Retail Outlet of Petroleum Class A & B Belonging to H.P.Oil Corporation Ltd.), at San Martin Marg, Chanakya Puri, New Delhi-110021 comprised of ground plus mezzanine floor only, was granted Fire Safety Certificate by this department vide letter No. F5/(3A)/DFS/2011/195, dated 26-08-2011. The premises was re-inspected by the officer concerned of this department on 31-12-2014 in the presence of Sh. Inder Mohan Bansawal (Owner) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class Mixed (Petrol Pump and Service Station) with effect from14.01/2015 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued ...14.01/2015 at New Delhi by.



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333

Copy to:-

1. The Medical Officer,(Health)
N.D.M.C, Palika Kendra, New Delhi-110001.
2. Sh. Inder Mohan Bansawal (Proprietor),
M/S Bansawal Service Station, San Martin Marg,
Chanakya Puri, New Delhi-110021.



Conditions for the validity of fire safety certificate are overleaf:-

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

H/10

INSPECTION REPORT

- 1. Name & address of the building : M/S Basiwal Service Station(Retail Outlet of Petroleum Class A & B Belonging to H.P.Oil Corporation Ltd.), at San Martin Marg, Chanakya Puri, New Delhi-110021.
- 2. Building is comprised of : Ground plus mezzanine floor.
- 3. Type of Occupancy : Mixed Occupancy (Patrol Pump and Service Station).
- 4. Type of Case : Renewal
- 5. Details of Previous NOC : No.F5/(3A)/DFS/2011/195, Dated 26.08.2011.
- 6. Fire Safety direction letter No : No.F5/(3A)/DFS/BP/99/375, dated 24.08.99
- 7. Date of Inspection : 31.12.14.
- 8. Name of the Inspecting Officers: : Vedpal (ADO)
- 9. Name and designation of Officer from the building side : Sh. Inder Mohan Bansiwal (Owner)
- 10. Year of Construction : 1999.
- 11. Applicant's letter No : Nil, dated 08.12.14

| S.No | Minimum Standards on fire prevention and fire safety as per old NOC. | Requirement | Provided at Site | Remarks MR/NMR |
|----------------------|--|-----------------|------------------|----------------|
| 1 | Access to building | | | |
| | Road width | 6 m | 12 m | MR |
| | Gate width | N.A. | N.A. | N.A. |
| | Width of internal road | N.A. | N.A. | N.A. |
| 2 | Number, Width, Type and Arrangement of Exits. | | | |
| | a. Number of Staircases | | | |
| | Upper Floor | 01no. | 01no. | MR |
| | Basement | N.A. | N.A. | N.A. |
| | B. Width of Staircases | | | |
| | Upper Floor | 1.2m | 1.2m | MR |
| | Basement | N.A. | N.A. | N.A. |
| | c. Protection of exits | | | |
| | Fire check door | N.A. | N.A. | N.A. |
| | Pressurization | N.A. | N.A. | N.A. |
| | e. No. of continuous staircases to terrace | N.A. | N.A. | N.A. |
| g. Width of Corridor | N.A. | N.A. | N.A. | |
| h. Door Size | 1 m | 1m | MR | |
| 3 | Compartmentation | | | |
| | Fire check door | N.A. | N.A. | N.A. |
| | Sealing of electrical shafts | N.A. | N.A. | N.A. |
| | Fire rating of shaft door | N.A. | N.A. | N.A. |
| | Water curtain | N.A. | N.A. | N.A. |
| | Fire Dampers | N.A. | N.A. | N.A. |
| 4 | Smoke Management System. | | | |
| | Basement | 30a/c per hour | N.A. | N.A. |
| | Upper floor | 12 a/c per hour | N.A. | N.A. |

M/S Basiwal Service Station, San Martin Marg, Chanakya Puri, New Delhi-110021.

| | | | | |
|----|---|---------------------------------|-----------------------------------|------|
| 5. | Fire Extinguisher | | | |
| | Total numbers | 10 nos. | 16 nos. | MR |
| | Types | CO ₂ & ABC,DCP, AFFF | CO ₂ DCP,ABC AFFF Type | MR |
| | IS marking | ISI marked | ISI marked | MR |
| 6 | First-aid-Hose Reels. | | | |
| | Total numbers of each floor | N.A. | N.A. | N.A. |
| | Length of hose reel hose | N.A. | N.A. | N.A. |
| | Nozzle diameter | N.A. | N.A. | N.A. |
| 7 | Automatic fire detection and alarming system. | | | |
| | Type of detectors | N.A. | N.A. | N.A. |
| | Location of main panel | N.A. | N.A. | N.A. |
| | Location of repeater panel | N.A. | N.A. | N.A. |
| | Alternate source of power | N.A. | N.A. | N.A. |
| | Hooters | N.A. | N.A. | N.A. |
| 8 | MOEFA | N.A. | N.A. | N.A. |
| 9 | Public address System. | N.A. | N.A. | N.A. |
| 10 | Automatic Sprinkler System. | | | |
| | Basement | N.A. | N.A. | N.A. |
| | upper floor | N.A. | N.A. | N.A. |
| | sprinkler above false ceiling | N.A. | N.A. | N.A. |
| 11 | Internal Hydrants | | | |
| | size of riser/down-comer | N.A. | N.A. | N.A. |
| | Number of hydrants per floor | N.A. | N.A. | N.A. |
| | Hose Box | N.A. | N.A. | N.A. |
| 12 | Yard Hydrants. | | | |
| | Total number of hydrants | N.A. | N.A. | N.A. |
| | Hose Box | N.A. | N.A. | N.A. |
| 13 | Pumping Arrangements. | | | |
| | ➤ Ground Level | N.A. | N.A. | N.A. |
| | ➤ Discharge of main Pump | N.A. | N.A. | N.A. |
| | ➤ Head of Main Pump | N.A. | N.A. | N.A. |
| | ➤ Number of main pumps | N.A. | N.A. | N.A. |
| | ➤ Jockey pump out put | N.A. | N.A. | N.A. |
| | ➤ Jockey pump head | N.A. | N.A. | N.A. |
| | ➤ Standby pump out put | N.A. | N.A. | N.A. |
| | ➤ Standby pump Head | N.A. | N.A. | N.A. |
| | ➤ Auto Starting /Manual stopping | N.A. | N.A. | N.A. |
| | ➤ Pump House Access | N.A. | N.A. | N.A. |
| | ➤ Terrace Level | N.A. | N.A. | N.A. |
| | ➤ Discharge of pump | N.A. | N.A. | N.A. |
| | ➤ Head of the Pump | N.A. | N.A. | N.A. |
| | ➤ Power supply | N.A. | N.A. | N.A. |
| | ➤ Auto Starting of pump | N.A. | N.A. | N.A. |
| | | N.A. | N.A. | N.A. |

M/S Basiwal Service Station, San Martin Marg, Chanakya Puri, New Delhi-110021.

| | | | | |
|----|--|----------|----------------------------------|------|
| 14 | Captive Water Storage for Fire Fighting. | | | |
| | Underground tank capacity | N.A. | N.A. | N.A. |
| | Draw-off connection | N.A. | N.A. | N.A. |
| | Fire service inlet | N.A. | N.A. | N.A. |
| | Access to tank | N.A. | N.A. | N.A. |
| | Overhead Tank capacity | N.A. | N.A. | N.A. |
| 15 | No Smoking Signage.(Hindi & English) | Required | Provided in Hindi And English | MR |
| 16 | Provision of Lifts. | | | |
| | Pressurization of Lift Shaft | N.A. | N.A. | N.A. |
| | Pressurization of Lift lobby | N.A. | N.A. | N.A. |
| | Communication in lift car | N.A. | N.A. | N.A. |
| | Firemen's grounding switch | N.A. | N.A. | N.A. |
| | Lift Signage | N.A. | N.A. | N.A. |
| 17 | Standby power supply | N.A. | Provided DG Set 50KVA | N.A. |
| 18 | Refuge Area. | | | |
| | Total area | N.A. | N.A. | N.A. |
| | Location | N.A. | N.A. | N.A. |
| 19 | Fire Control Room | | | |
| | Detector system panel | N.A. | N.A. | N.A. |
| | Flow switch panel | N.A. | N.A. | N.A. |
| | PA system panel | N.A. | N.A. | N.A. |
| | Batter backup | N.A. | N.A. | N.A. |
| | Building Floor Plans | N.A. | N.A. | N.A. |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N.A. | N.A. | N.A. |

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the FSC issued vide letter No: F5/(3A)/DFS/2011/195, dated 26.08.2011, renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

D.O. (South)

9/1/15

5/1/15

Signature of the Inspecting Officer
Name: Vedpal
Designation: ADO