

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. FG/DFS/MS/AH/2015/W2/88

Dated: 15/01/2015

**FIRE SAFETY CERTIFICATE**

Certified that **Rajvansh Garden, Lampur Road, Lampur, Delhi-110040** comprised of **Basement + Ground Floor** owned / occupied by **Sh Vijay (Owner)** has already been issued fire safety certificate vide Letter **NO F-6/DFS/MS/GH/2011/1231 dated 15/06/2011**. The premise was re-inspected by the officer concerned from this department on **17/12/2014** in the presence of **Sh Vijay** have deem complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy **Class Group-D (Assembly Building)** not more than 300 persons with effect from **15/01/2015** for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

1. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
2. The fire suppression / protection arrangements provided are to minimize losses, if maintained in good working condition. These systems cannot give a guarantee that there will be no fire or losses in the event of one.
3. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
4. This report may not in any way be treated as regularization of unauthorized construction, if any. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. The trained fire fighting staff should be available round the clock.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 15/01/2015 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Ph: 011-23414250

**Copy to:**

1. The Asstt. Commissioner, North Delhi Municipal Corporation, Narela Zone, Delhi for information.
2. Sh. Vijay. Rajvansh Garden, Lampur Road, Lampur, Delhi-110040

B + G2. floor

**INSPECTION REPORT**

1. Name & address of the building : Rajvansh Garden, Campus Road, Campus
2. Type of Occupancy : Assembly - Group 'D' Sechi-40
3. Type of Case : New Case/Renewal
4. Details of previous NOC : Letter No. A-6/DP2/MS/FH/2011/123 Dated: 15-6-11
5. Fire Safety directives letter No : NBC Part IV
6. Date of inspection : 17-12-14
7. Name of the Inspecting Officers : ADD (BW)
8. Name and designation of officers from the building side : sh. Vijay, owner
9. Year of Construction : \_\_\_\_\_
10. Applicant's letter No. : ft Nonic dt. 3-11-14

PA. 3 area

CA. 100 m<sup>2</sup>

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	<u>Accessable</u>	<u>Accessable</u>	<u>MR</u> ✓
	• Gate width	<u>do</u>	<u>do</u>	<u>MR</u> ✓
	• Width of internal road	<u>do</u>	<u>do</u>	<u>MR</u> ✓
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	<u>-</u>	<u>-</u>	<u>-</u>
	• Upper Floors	<u>-</u>	<u>-</u>	<u>-</u>
	• Basements	<u>01</u>	<u>01</u>	<u>MR</u> ✓
	b. Width of staircases	<u>-</u>	<u>-</u>	<u>-</u>
	• Upper Floors	<u>-</u>	<u>-</u>	<u>-</u>
	• Basements	<u>old case</u>	<u>old case</u>	<u>old case</u> ✓
	c. Protection of exits	<u>-</u>	<u>-</u>	<u>-</u>
	• Fire check door	<u>-</u>	<u>-</u>	<u>-</u>
	• Pressurization	<u>-</u>	<u>-</u>	<u>-</u>
	e. No. of continuous staircases to terrace	<u>-</u>	<u>-</u>	<u>-</u>
	g. Width of Corridor	<u>-</u>	<u>-</u>	<u>-</u>
	h. Door Size	<u>old case</u>	<u>old case</u>	<u>old case</u> ✓



N-7

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>			
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour		
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	6 ABC ISI marked	6 ABC yes	MR ✓ MR ✓ MR ✓
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	one 30 m 5 mm	P P P	MR ✓ MR ✓ MR ✓
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>			
8	<b>MOEFA</b>	R	P	MR ✓
9	<b>Public Address System.</b>	R	P	MR ✓
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	R — —	P — —	MR ✓ — —
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	— — —	— — ✓	— — ✓

12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	2 R	P	MR ✓
	• Hose Box	2	P	MR ✓
13	<b>Pumping Arrangements.</b>			
	• Ground Level	—	—	—
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/ Manual stopping	—	—	—
	➤ Pump House Access	—	—	—
	• Terrace level	—	—	—
	➤ Discharge of pump	900 LPM	P	MR ✓
	➤ Head of the pump	40 M	P	MR ✓
	➤ Power Supply	—	—	—
	➤ Auto Starting of pump	—	—	—
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	—	—	—
	➤ Draw-off connection	—	—	—
	➤ Fire service inlet	—	—	—
	➤ Access to tank	—	—	—
	• Overhead Tank capacity	10,000 lbs	P	MR ✓
15	<b>Exit Signage.</b>	R	P	MR ✓
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	<b>Standby power supply</b>	R	P	MR ✓



18	<b>Refuge Area.</b>	➤ Total Area			
		➤ Location			
19	<b>Fire Control Room</b>	• Detector System Panel			
		• Flow Switch Panel			
		• PA System Panel			
		• Batter backup			
		• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:				

N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-4/D.P.S./M.S./F.H/2011/1231 dated 15.6.11... Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

D.O. Singh

Designation

Chh. Sharma  
28-12-14  
ADD(BW)