

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/2015/W2/33

Dated: 08/01/2015

**FIRE SAFETY CERTIFICATE**

Certified that Shradha Cosmetics, H-258, Sector-3, Bawana Industrial Area, Bawana Delhi-110039. Comprised of Basement + Ground + Three upper floors thus less than 15 Meters owned / occupied by Shradha Cosmetics was granted NOC by this department vide letter No. F6/DFS/MS/Cos/2011/3264 Dated 30/11/2011. The premise was re-inspected by the officers concerned of this department on 10/12/2014 in the presence of Sh. Rajeev Sawhney of the factory and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the Fire Safety Certificate is renewed and premises is fit for Class-G (G-II) Industrial with effect from 08/01/2015 for a period of three years subject to conditions printed below.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 08/01/15 at New Delhi by

  
(VIPIN KENTAL)  
For Chief Fire Officer  
Ph: 011-23846352

**Copy to:**

1. Shradha Cosmetics, H-258, Sector-3, Bawana Industrial Area, Bawana Delhi-110039
2. The Assistant Drugs Controller & Licensing Authority, Govt of National Capital Territory of Delhi, F-17, Karkardooma, New Delhi-110032

**INSPECTION REPORT**

1. Name & address of the building : Shradha Cosmetics, H258, Sec-03, Bawana Industrial Area, Bawana Delhi-110039.
2. Type of Occupancy : Industrial G-2 (B + G + 3 upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F6/DFS/MS/Cos/2011/3264 Dated – 30/11/2011
5. Fire Safety directives letter No : Nil
6. Date of inspection : 10/12/2014
7. Name of the Inspecting Officers : Do (NW) S.S. Tuli
8. Name and designation of officers from the building side : Sh. Rajiv Sawhney
9. Year of Construction : 2005
10. Applicant's letter No. : Nil Dated 25/11/2014

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	9 mtr	10 mtr	M/R ✓
	• Gate width	5 mtr	6 mtr	-- ✓
	• Width of internal road	--	--	-- ✓
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	01	01	M/R ✓
	• Upper Floors	Old case	Old case	M/R ✓
	• Basements	Old case	Old case	M/R ✓
	b. Width of staircases			
	• Upper Floors	Old case	Old case	M/R ✓
	• Basements	Old case	Old case	M/R ✓
	c. Protection of exits			
	• Fire check door	Old case	Old case	M/R ✓
	• Pressurization	--	--	--
	e. No. of continuous staircases to terrace	ONE	ONE	M/R ✓
	g. Width of Corridor	--	--	--
	h. Door Size	--	--	--

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
		--	--	--
		--	--	--
		--	--	--
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour	N/A	N/A
		12 a/c per hour	N/A	N/A
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	10	<b>10</b>	<b>M/R</b> ✓
		ISI marked	<b>ABC</b>	<b>M/R</b> ✓
			<b>P</b>	<b>M/R</b> ✓
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	On at each floor	<b>P</b>	<b>M/R</b> ✓
		30 m	<b>P</b>	<b>M/R</b> ✓
		5 mm	<b>P</b>	<b>M/R</b> ✓
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	N/A	N/A	N/A
		--	--	--
		--	--	--
		--	--	--
		--	--	--
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	<b>R</b>	<b>P</b>	<b>M/R</b> ✓
		--	--	--
		--	--	--
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	N/A	N/A	N/A
		--	--	--
		--	--	--

12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	--	--	--
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	--	--	--
	➤ Head of Main pump	--	--	--
	➤ Number of main pumps	--	--	--
	➤ Jockey Pump out put	--	--	--
	➤ Jockey pump head	--	--	--
	➤ Standby Pump out put	--	--	--
	➤ Standby Pump Head	--	--	--
	➤ Auto Starting/ Manual stopping	--	--	--
	➤ Pump House Access	--	--	--
	• Terrace level			
	➤ Discharge of pump	<b>900 LPM</b>	<b>P</b>	<b>M/R</b>
	➤ Head of the pump	<b>40 m</b>	<b>P</b>	<b>M/R</b>
	➤ Power Supply	<b>R</b>	<b>P</b>	<b>M/R</b>
	➤ Auto Starting of pump	<b>R</b>	<b>P</b>	<b>M/R</b>
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	--	--	--
	➤ Draw-off connection	--	--	--
	➤ Fire service inlet	--	--	--
	➤ Access to tank	<b>10000 Ltr</b>	<b>P</b>	<b>M/R</b>
15	<b>Exit Signage.</b>	<b>R</b>	<b>P</b>	<b>M/R</b>
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	--	--	--
	• Communication In lift Car	--	--	--
	• Fireman's Grounding Switch	--	--	--
	• Lift Signage	--	--	--

Shradha Cosmetics, H258, Sec-03, Bawana Industrial Area, Bawana, Delhi

17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	—	—	—
19	<b>Fire Control Room</b>			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F6/DFS/MS/Cos/2011/3264 Dated 30/11/2011** Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

*[Handwritten Signature]*  
 24/12/14  
 DO (100)

