

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No. R/D/F/MS/EN/2014/W2/47

Dated: 09/01/15

FIRE SAFETY CERTIFICATE

Certified that the M/s Lalji Foods located at **Ground Floor & First Floor, A2/43, Rajouri Garden, New Delhi - 110027** in a building comprised of Basement + Ground + 3 Upper Floors owned/ occupied by M/s Lalji Foods have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 10-12-2014 in the presence of Mr. Manoj Rajput (Manager - Accounts) and found that the said building that the premises is fit for occupancy class "Assembly" Group D with effect from 09/01/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/01/15 at New Delhi by.

S
5/11
(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250

Copy to:

1. Sh. Kishan Kumar Aggarwal,
M/s Lalji Foods, Ground Floor & First Floor,
A2/43, Rajouri Garden, New Delhi.
2. Dy. Health Officer, West Zone,
SDMC, Public Health Department,
Vishal Enclave, New Delhi.

OK
Only

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per Building Bye Laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1. Name & address of the building: M/s Lalji Foods, Ground & First Floor, A2/43, Rajouri Garden, New Delhi.
2. Type of Occupancy : Assembly (Restaurant) (Basement + Ground + 3 Upper Floors)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2013/2308 dated 24-09-2013
6. Date of inspection : 10-12-2014
7. Name of the Inspecting Officer : Mukesh Verma, ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Manoj Rajput (Manager – Accounts)
9. Year of Construction : 2014
10. Applicant's letter No. : D-1672/DHO/WZ/2014 dated 24-07-2014

Basement – Storage, Ground & First Floor – Restaurant
 Second & Third Floor - Empty

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	24 m 5 m NA	Provided On Main Road NA	MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	3 3	Provided Provided	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	2X1.5m & 1X1m 2X1.5m & 1X1m	153 cm, 162cm & 103 cm 2X160cm, 103 cm & 80 cm	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required Required	Provided Provided	MR MR
	d. No of continuous staircase to terrace	3	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2X2m	2X2m & 145 cm	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical 	Required Required	Provided Provided	MR MR

	shafts			
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	18 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	2	Provided	MR
	• Hose Box	2	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	2280 lpm	Provided	MR
	➤ Head of main pump	60 m	Provided	MR
	➤ Number of main pumps	1	Provided	MR
	➤ Jockey pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	60 m	Provided	MR
	➤ Standby Pump out put	2280 lpm	Provided	MR
	➤ Standby Pump Head	60 m	Provided	MR
	➤ Auto Staring/Manual	Required	Provided	MR

	stopping			
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	50,000 litres	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision Of Lifts : No lift is installed			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

Signature of the Inspecting Officer
Name
Designation

Mukesh Verma
18/12/14
MUKESH VERMA
ADO (MWS)

Signature of the Inspecting Officer
Name
Designation