

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No: F.6/DFS/MS/School/2015/ 52/53

Dated: 09/01/15

FIRE SAFETY CERTIFICATE

Certified that the building of **S.D.M.C. Primary School**, B-3A, Janak Puri, New Delhi - 110058 is comprised of ground floor plus one upper floor was issued NOC by this department vide letter No.F.6/DFS/MS/10/906 dated 25.03.2010 for ground floor only. The School building was re- inspected by the officer concerned of this department on 02.01.2015 in the presence of Sh. Ramanand (Chokidar) and found that the school management (S.D.M.C) have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No- F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and that the school building (**Ground floor plus one upper floor**) is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on 09/01/15 at New Delhi


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph: 011-23414333

Copy to: -

1. The Principal,
S.D.M.C. Primary School,
B-3A, Janak Puri, New Delhi-58.
2. Director of Education,
South Delhi Municipal Corporation
23rd floor, Dr. S.P.M Civic Centre,
Minto Road, New Delhi-110002.

INSPECTION REPORT

1. Name & address of the building: S.D.M.C Primary School, B-3A, Janak Puri, N.D.
2. Type of Occupancy : Educational (School)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F.G/DFS/MS/10/906 Dated 25.03.20
5. Fire Safety directives letter No : -
6. Date of inspection : 02.01.2015
7. Name of Inspecting Officer : A.D.O P.S. Dahiya
8. Name and designation of officers
From the building side : Sh. Ramanand (Chokidar)
9. Year of Construction : 2012-2013
10. Applicant's letter No. : Nil dated 12.12.2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	09mtr	MR
	• Gate width	-	420 cms	MR
	• Width of internal road	-	-	-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Two	Two	MR
	• Basements	-	-	No Basement
	b. Width of staircases			
	• Upper Floor	-	125cms, 148cms	MR
	• Basements	-	-	No Basement
	c. Protection of exits			
	• Fire check door	-	-	-
	• pressurization	-	-	-
	d. No. of continuous staircases to terrace	-	Two	-
	e. Width of Corridor	-	210cms, 200cms	-
	f. Door Size	-	115cms x 197cms	-
3.	Compartmentation			
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	Sealed	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4.	Smoke Management System			
	• Basements	30 a/c per hour	-	No Basement
	• Upper floors		Natural Ventilation	MR

M/S

B-3A, Janak Puri, New Delhi-110058.

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-	-	-
15.	Exit Signage.	<i>Required</i>	<i>Provided</i>	<i>MR</i>
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	<i>No Lift</i>
		-	-	<i>-do-</i>
		-	-	<i>-do-</i>
		-	-	<i>-do-</i>
		-	-	<i>-do-</i>
17.	Standby power supply	-	-	-
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	-	-	-
		-	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	-	-	-

N/G.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.G/DFS/MS/10/906 dated 25.03.2010 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Note:- The school building is comprised of Ground floor plus one upper floor. The previously FSC issued vide letter No. F.G/DFS/MS/10/906 dated 25.03.2010 for Ground Floor only, as the building is comprised of Ground floor only (Tin shed). The FSC is recommended for Ground floor plus one upper floor.


Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer

Signature of Inspecting Officer

Name

Designation

D. S. S.