

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/2015/W2/64

Dated: 13/01/2015

FIRE SAFETY CERTIFICATE

Certified that **Storage of Petroleum Class A & B (20 KL each)** located at **Sector-3, DSIDC, Police Station, Bawana, Delhi** Comprised of **Single Story Building** owned / occupied by **Police Station, Bawana**, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 & verified by the officer concerned of this department on **03/11/2014** in the presence of **Inspector Anil Kumar (P.S Bawana)** and that the premises fit for occupancy class **Hazardous (Group-J)** occupancy with effect for from **13/01/2015** for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

1. "No Smoking "and "Not to use mobile Phone" sign board should be displayed in such a manner as to be easily readable by all persons.
2. No Trade Susceptible to Cause Ignition Petroleum vapors by generating heat, mechanical / electric spark should be allowed within the premises and its vicinity.
3. 04 no's of Co2 gas type ISI capacity of 4.5 kg, 02 no's of ABC stored pressure power type ISI capacity 05 kg and 01 numbers of AFFF type ISI capacity 50 ltrs should be provided and maintained in proper working order.
4. The workers employed at the petrol pump must be taught the correct method of operation and maintenance of record of the extinguishers be ensured.
5. Overhead electric cable should not be allowed across the licensed premises.
6. Boundary wall of 6 feet high with fencing over the wall should be provided.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 13... / 01... /2015 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Addl. Dy. Commissioner of Police, Outer District, Delhi
2. The Joint commissioner of Police, Licensing, Police Station (1st floor) Defence Colony, New Delhi.
3. The S.H.O Bawana Police Station, Outer District, Delhi.