

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110 001**

No. F6/DFS/MS/School/2015/SZ/68

Dated: 14/01/15

**FIRE SAFETY CERTIFICATE**

Certified that M/S The Shri Ram School, D-3 Street, Vasant Vihar, New Delhi-110057, comprises of Basement, Ground plus two upper floors (One Block), and ground plus three upper floors(One Block), both blocks are interconnected was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2011/3661, dated 22-12-2011. The premises was re-inspected by the officers concerned of this department on 24-12-2014 in the presence of **Sh. Chitra Singh Dumoliya (Administrator)** and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Educational** with effect from ...14/01/2015 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on...14/01/2015 at New Delhi by.



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333



Copy to:-,

1. Principal,

The Shri Ram School, D-3 Street, Vasant Vihar, New Delhi-110057.

2. Dy. Director of Education,  
Old Secretariat, Civil Lines,  
Delhi.

**Conditions for the validity of fire safety certificate are overleaf:-**

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

M/13

**INSPECTION REPORT**

- 1. Name & address of the building : The Shri Ram School, D-3 Street, Vasant Vihar, New Delhi-110057.
- 2. Building is comprised of : B+G+2(From one side one block and G+3 From other side one block). Both blocks are interconnected.
- 3. Type of Occupancy : Education
- 4. Type of Case : Renewal.
- 5. Details of Previous NOC : No.F6/DFS/MS/School/2011/3661, dated 22.12.2011.
- 6. Fire Safety direction letter No : No.F.6/DFS/MS/95/154, dated- 09.02.95 & Circular No.262-362.
- 7. Date of Inspection : 24.12.14
- 8. Name of the Inspecting Officers: : Vedpal (ADO)
- 9. Name and designation of Officer from the building side : Sh. Chitra Singh Dumoliya (Administrator)
- 10. Year of Construction : 1995.
- 11. Applicant's letter No : Nil, dated 09.12.14

S.No	Minimum Standards on fire prevention and fire safety as per rules.	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	9 m	MR
	Gate width	5m	4m.	MR(old case)
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases	.		
	Upper Floor	2nos.	2nos.	MR
	Basement	2nos.	2nos.	MR
	B. Width of Staircases			
	Upper Floor	1.5 m(each)	1.5m (each)	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	g. Width of Corridor	1no.	1no.	MR
h. Door Size				
	1.5 m	1.5 m	MR	
	1 m	1m	MR	
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	Exhaust fans provided	MR
	Upper floor	12 a/c per hour	N.A.	N.A.



5.	Fire Extinguisher			
	Total numbers	16 nos.	30 nos.	MR
	types	CO <sub>2</sub> & ABC	ABC Type	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	02nos.	02 nos.	MR.
	Length of hose reel hose	30m	30m	MR.
	Nozzle diameter	5cm	5cm	MR.
7	Automatic fire detection and alarming system.			
	Type of detectors in Auditorium only	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	upper floor	N.A.	N.A.	N.A.
	stage of auditorium	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of down-comer	N.A.	100mm	N.A.
	Number of hydrants per floor	N.A.	2nos.	N.A.
	Hose Box	N.A.	2nos.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	07nos.	N.A.
	Hose Box	N.A.	07nos.	N.A.
13	Pumping Arrangements.			
	➤ Ground Level	N.A.	Provided	N.A.
	➤ Discharge of main Pump	N.A.	900lpm	N.A.
	➤ Head of Main Pump	N.A.	40m	N.A.
	➤ Number of main pumps	N.A.	01no.	N.A.
	➤ Jockey pump out put	N.A.	180lpm	N.A.
	➤ Jockey pump head	N.A.	40m	N.A.
	➤ Standby pump out put	N.A.	900lpm	N.A.
	➤ Standby pump Head	N.A.	40m	N.A.
	➤ Auto Starting /Manual stopping	N.A.	Provided	N.A.
	➤ Pump House Access	N.A.	Provided	N.A.
	➤ Terrace Level	01no.	01no.+1jockey.	MR.
	➤ Discharge of pump	450LPM	450LPM+180LPM	MR
	➤ Head of the Pump	40m(each)	40 (each)	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

112

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A	50000Ltrs.	MR
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A	Provided	MR
	Overhead Tank capacity	5000 liters	10000Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	Provided	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/DFS/MS/School/2011/3661, dated 22.12.2011 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up please.

Signature of the Inspecting Officer  
Name : Vedpal

Designation: ADO



6/1/15