

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001.

No. F.6/DFS/MS/EH/2014/ 52/1631

Dated: 23/12/14

FIRE SAFETY CERTIFICATE

Certified that the **Haldi Ram Restaurant**, 4B/16, Najafgarh Rd, Tilak Nagar, New Delhi-110018, is in the building comprised of basement, ground floor plus two upper floors but the restaurant is running at ground plus two upper floors only of above said building and the basement is not in use. The restaurant having two exits owned/occupied by M/s Haldiram Products Pvt. Ltd. The Restaurant was inspected by the officer concerned of this department on 09.12.2014 in the presence of Sh. Udit Awasthi (General Manager) and found that the M/s Haldiram Products Pvt. Ltd. have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the Restaurant (**at Ground plus two upper floors only**) is fit for occupancy class Group D assembly building w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on..... 23/12/14..... at New Delhi.



23/12

(DR. G. C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph.011-23414333

Copy to:-

1. The Manager,  
Haldi Ram Restaurant,  
4B/16, Najafgarh Rd, Tilak Nagar,  
New Delhi-110018.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per the building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Basement (Not in use), Ground Plus Two Upper Floors.  
(Haldi Ram Restaurant, 4B/16, Najafgarh Road, Tilak Nagar, New Delhi 110018.)

	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	—	Natural Ventilation	M/R
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	Three no's / floor ABC/CO2	Provided	M/R
			Provided	M/R
6.	<b>First-Aid Hose Reels</b>	ISI marked	ISI marked	M/R
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	Two 30 mtrs 5 mm	Provided	M/R
			Provided	M/R
			Provided	M/R
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Smoke & Heat	Provided	M/R
		—	Basement	M/R
		—	—	—
		Required	Provided	M/R
			Near exits	M/R
8.	<b>MOEFA</b>	Required	Provided	M/R
9.	<b>Public Address System</b>	Required	Provided	M/R
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	-	Provided	-
		Required	Provided in entire building	MR
11.	<b>Internal Hydrants</b>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants</li> <li>Hose Box</li> </ul>	100 mm	Provided	M/R
		02 No's	Provided	M/R
12.	<b>Yard Hydrants</b>	02 No.	Provided	M/R
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	—	—	—
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> </ul>	NA	2280 LPM	—
		NA	50 mtrs	—
		NA	01	—
		NA	180 LPM	—
		NA	50 mtrs	—
		NA	2280 LPM	—
		NA	50 mtrs	—

Basement (Not in use), Ground Plus Two Upper Floors.  
(Haldi Ram Restaurant, 4B/16, Najafgarh Road, Tilak Nagar, New Delhi 110018.)

	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/Manual Stopping</li> </ul>	NA	Provided	Provided
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	—	—	—
	<ul style="list-style-type: none"> <li>• Terrace level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	Required	900 LPM	M/R
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	Required	40 mtrs	M/R
	<ul style="list-style-type: none"> <li>➤ Power Supply</li> </ul>	Required	Provided	M/R
	<ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>	Required	Provided	M/R
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> </ul>	NA	50,000 Ltrs	Provided
	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>	—	—	—
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	—	-	-
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	—	—	—
	<ul style="list-style-type: none"> <li>• Overhead Tank capacity</li> </ul>	10,000 Ltrs	10,000 Ltrs	M/R
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	M/R
<b>16.</b>	<b>Provision of Lifts.</b>	<b>(No Lift)</b>		
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Pressurization of Lift lobby</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Communication In lift Car</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Fireman's Grounding Switch</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
<b>17.</b>	<b>Standby power supply</b>	Required	Provided (DG set 260 KVA)	M/R
<b>18.</b>	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Location</li> </ul>	N/A	N/A	N/A
<b>19.</b>	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Flow Switch Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• PA System Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Battery backup</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

N/S

Basement (Not in use), Ground Plus Two Upper Floors.  
(Haldi Ram Restaurant, 4B/16, Najafgarh Road, Tilak Nagar, New Delhi 110018.)

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Note: - The restaurant is at ground plus two upper floors, the basement is not in use and the total capacity of water tank is 60,000 ltrs (U/G-50,000 ltrs + O/H -10000 ltrs) and separate DG supply (125 KVA) has also been extended to Fire Pump Panel, as per the letter submitted by the authorized signatory.

 S.K. Tomar  
11/12/14

Signature of Inspecting Officer

Name:- S.K. Tomar

Designation:- Divisional Officer

Signature of Inspecting Officer

Name:-

Designation:- 