

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/2014/School/w2/139

Dated: 30/01/2015

FIRE SAFETY CERTIFICATE

Certified that Bright Star Model School, 154, 41 feet Road, Uttaranchal Enclave, Kamal Pur, Burari, Delhi-110084 comprised of Ground + One Upper Floor owned/occupied by Bright Star Model School has already been issued fire safety certificate vide letter no. F-6/DFS/MS/2007/3840 dated 27/12/2007. The premises now ground + two upper floor. The same was re-inspected by the officer from this department on dated 23/12/2014 in the presence of Mr. Rajesh Chauhan (Manager) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 30/01/2015 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 30/01/15 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Manager, Bright Star Model School, 154, 41 feet Road, Uttaranchal Enclave, Kamal Pur, Burari, Delhi-110084
2. The Director of Education, Old Secretariate, Delhi

A-9

Previous - G₁ + one floor
 Present - G₂ + two floors

INSPECTION REPORT

1. Name & address of the building: Bright star model school, 154 Uthmanchad
2. Type of Occupancy: Educational
3. Type of Case: New Case / Renewal
4. Details of previous NOC: F-6/DPS/MS/2007/3840 dt. 27.12.07
5. Fire Safety directives letter No: Dir. of Edu. dt. 01.8.2011
6. Date of inspection: 23.12.14
7. Name of the Inspecting Officers: AOO (BWO)
8. Name and designation of officers from the building side: Sh. Rajesh Chauhan, manager
9. Year of Construction: 2006 & 2012
10. Applicant's letter No: NIL dt. 8.12.14

Plot area: 1400 sq. yds. Covered area: 792 sq. yds. No.'s of students: 216 No.'s of classrooms: 18
5 room for other purpose

	Minimum Standards on fire prevention and fire safety U/R 33	Circular Dir. of Edu Requirement/ NBC	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR ✓
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases			
	• Upper Floors	—	—	—
	• Basements	01	02	MR ✓
b.	Width of staircases			
	• Upper Floors	—	—	—
	• Basements	old case	old case	old case ✓
c.	Protection of exits			
	• Fire check door	—	—	—
	• Pressurization	—	—	—
e.	No. of continuous staircases to terrace	R	P	MR ✓
g.	Width of Corridor	—	—	—
h.	Door Size	old case	old case	old case ✓

3	Compartmentation.				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 				
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour			
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	GABC ISI marked	6 ABC yes	MR MR MR	/
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	one 30 m 5 mm	P P P	MR MR MR	/
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 				
8	MOEFA				
9	Public Address System.				
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 				
11	Internal Hydrants				
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 				

18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

Note:-General requirements for school as per Director of Education Circular dated...01./03../2017

1. Escape route..... clear
2. LPG cylinders in laboratories NO
3. Electric wiring .. concealed MCB and ELCB Provided
Electric circuit.....
4. Electric meter board Not below 5/2
5. Basement use as per BBL 1983..... N/A
6. Emergency telephone no. board..... Provided
7. Generator set..... NO

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DPS/MS/2007/3240 dated 27./12./07 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

DO (A/W)
30/12/14

Delhi
28.12.14

ABO (B/W)