

(8)

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F610FS/MS/School/ND2/2015/94

Dated: 19/01/2015

FIRE SAFETY CERTIFICATE

Certified that D A V Public School, Sector – 07, Rohini, Delhi 110085 comprised of Ground + Three Upper Floors owned/occupied by D A V Public School have complied with the fire prevention and fire safety requirements in accordance with NBC- Part IV and verified by the officer concerned of Fire Service on 05/01/2015 in the presence of Sh. Surinder Mohan and that the building / premises is fit for occupancy of Educational building with effect from 19/01/2015 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 19/01/2015 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, D A V Public School, Sector – 07, Rohini, Delhi 110085 (ID. 1413257)
2. The Director of Education, Old Secretariat, Delhi

INSPECTION REPORT**Ground + Three Upper Floor**

1. Name & address of the building : D.A.V Public School, Sector 7, Rohini, Delhi
2. Type of Occupancy : Educational (ID 1413257)
3. Type of Case : New Case
4. Details of previous NOC : nil
5. Fire Safety directives letter No : NBC Part IV
6. Date of inspection : 05/01/2015
7. Name of the Inspecting Officers : DO (NW)
8. Name and designation of officers
from the building side : Sh. Surinder Mohan
9. Year of Construction : 1994-2006
10. Applicant's letter No. : DAV/PS/RHN/2014/835 dated 04/12/2014

Plot Area- 3.184 Acre Covered Area- 5155.69 Sq. Yds. NOS- 3530 No of Class Room-108 + 05

| | Minimum Standards on fire prevention and fire safety U/R 33 | Dir. of Edu. Requirement | Provided at site | Remarks MR/NMR |
|---|---|--------------------------|---|----------------|
| 1 | Access to building | | | |
| | • Road width | 6 m | P | M/R |
| | • Gate width | 5 m | P | M/R |
| | • Width of internal road | -- | -- | -- |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 04 | 04 | M/R |
| | • Basements | N/A | N/A | N/A |
| | b. Width of staircases | | | |
| | • Upper Floors | 1.5 m x 2 | (1) 175 (2) 136-141 cm (3) 180 (4) 141-142cm | M/R |
| | • Basements | -- | -- | -- |
| | c. Protection of exits | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Pressurization | -- | -- | -- |
| | e. No. of continuous staircases to terrace | 02 | 02 | M/R |
| | g. Width of Corridor | N/A | N/A | N/A |
| | h. Door Size | 01 mtr | P | M/R |
| 3 | Compartmentation. | | | |

| | | | | |
|----|---|----------------------------------|---------------------------------|---------------------------------|
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 4 | Smoke Management System. | | | |
| | <ul style="list-style-type: none"> • Basements • Upper floors | 30 a/c per hour | N/A | N/A |
| | | 12 a/c per hour | N/A | N/A |
| 5 | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers • Types • IS marking | One @ 300 mtr } ISI marked | 30 ✓ ABC + co2 Yes | M/R M/R M/R |
| 6 | First-Aid Hose Reels. | | | |
| | <ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter | 03 at each floor 30 m 5 mm | 03 P P | M/R M/R M/R |
| 7 | Automatic fire detection and alarming system. | | | |
| | <ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A |
| 8 | MOEFA | R | P | M/R |
| 9 | Public Address System. | N/A | N/A | N/A |
| 10 | Automatic Sprinkler System. | | | |
| | <ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling | N/A N/A N/A | N/A N/A N/A | N/A N/A N/A |
| 11 | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box | 04" 03 03 | P P P | M/R M/R M/R |

N-4

| | | | | |
|----|--|-----|---------|-----|
| 17 | Standby power supply | N/R | 125 KVA | M/R |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Batter backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | N/A | N/A | N/A |

Note: - General requirements for schools as per Director of Education circular dated

1. Escape route **Clear**.....
2. LPG cylinders in laboratories **Not in use**.....
3. Electric wiring **Concealed**.....
4. MCB and ELCB at Electric circuit ... **Provided**.....
5. Electric meter board **Not Below S/C**
6. Basement use as per BBL 1983 **N/A**.....
7. Emergency telephone no. board **Displayed**.....
8. Generator set **Provided**

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

Devi (w2)

Signature of the Inspecting Officer

Name

Designation

Devi
7/1/15
Devi (w2)