

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F&D/B/M/S/DMOT/2015/1422/96

Dated: 20/01/15

FIRE SAFETY CERTIFICATE

Certified that the Gopal Vatika (Banquet Hall/Marriage Home) at Plot No.603 to 612, Mandoli road, Shadara, Delhi-32, Comprised of ground floor only owned/occupied by M/s Gopal Vatika Banquet Hall/ Marriage Home have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on dated 14.11.2014 in the presence of Sh. Rakesh Sharma (Prop.) and found that the ground floor of building is fit for occupancy class D 'Assembly (Banquet Hall/ Marriage Home)' at Ground floor with effect from20.01.15... for a period of **three** years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions printed overleaf.

Issued on.....20/01/15.....at New Delhi by


(Dr.G.C.Misra)
Chief Fire Officer
Ph.011-23414333

To,
The Dy. Health Officer,
East Delhi Municipal Corporation, Health Department,
Shahdara (North) Zone, Shahdara, Delhi

Copy to-
Sh.Rakesh Sharma (Prop.)
M/s Gopal Vatika Banquet Hall/Marriage Home
Plot No.603 to 612, Mandoli road,
Shadara, Delhi-32,

CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : Gopal Vatika Banquet Hall at Plot No.603 to 612, Mandoli Road,Shahdara, Delhi.
2. Building is comprised of : Ground floor only
3. Type of Occupancy : Assembly (Banquet Hall)
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : NBC Part IV
7. Date of Inspection : 14.11.2014
8. Name of the Inspecting Officers: :ADO Suresh Singh & DO Virendra Singh
9. Name of the designation of Officer from the building side : Sh.Rakesh Sharma (Prop)
10. Year of Construction : 2009
11. Applicant's letter No : dated 09.09.14

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement/NBC	Provided at Site	Remarks MR/NM
1	Access to building			
	Road width	6 m	30 m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	N/A	01No.for terrace	MR
	Basement	N.A.	N.A.	N.A.
	b. Width of Staircases			
	Upper Floor	N/A	1.25 M	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	d. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	e. Width of Corridor	N.A.	N.A.	N.A.
	f. Number of door	02 Nos.	04 Nos.	MR
	g. Door Size	2 m	2 m each	MR
3	Compartmentation.			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A	N.A.	N.A.
	Ground floor	Required	Ventilated	M/R

5.	Fire Extinguisher			
	Total numbers	04 Nos.	06Nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	1 no.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters's location	N.A.	N.A.	N.A.
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants of each floor	1 no.	1 no.	MR
	Hose Box	01 no.	01 no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	Ground Level	N.A.	N.A.	N.A.
	Discharge of main Pump	N.A.	N.A.	N.A.
	Head of Main Pump	N.A.	N.A.	N.A.
	Number of main pumps	N.A.	N.A.	N.A.
	Jockey pump out put	N.A.	N.A.	N.A.
	Jockey pump head	N.A.	N.A.	N.A.
	Standby pump out put	N.A.	N.A.	N.A.
	Standby pump Head	N.A.	N.A.	N.A.
	Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	Pump House Access	N.A.	N.A.	N.A.
	Terrace Level			
	Discharge of pump	450 LPM	450 LPM	MR
	Head of the Pump	40 m	40 m	MR
	Power supply	Required	Provided	MR
	Auto Starting of pump	Required	Provided	MR

N13

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	10,000 Liters	10,000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Battery backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

S Singh
7.1.15

Signature of the Inspecting Officer
Name : Suresh Singh
Designation: ADO (Shad.)