

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax: 23412593, Tel: 011-23414333

No. F6/MS/DFS/SZ/EH/2014/ 52/95

Dated: 20/01/15

FIRE SAFETY CERTIFICATE

Certified that the M/S Harry's (a unit of Harry's India Pvt. Ltd.) located at shop no. 4, 2nd floor, Select City Walk Mall, A-3 Distt. Center, Saket, New Delhi-110017, comprised of basement, ground floor + two upper floors owned/occupied by A Unit of Harry's India Pvt. Ltd. The restaurant is running at second floor and inspected by the officer concerned of this department on 17/12/14 in the presence of Mr. Pramod Kumar(Manager) and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group – D, Assembly Building(Restaurant) with effect from ~~20/01/15~~ the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ~~20/01/15~~ at New Delhi by.


19/1
(Dr. G.C. Misra)
Chief Fire Officer

Copy to:-

- (1) Dy. Health Officer/ South Zone
Aurbindo Marg, Green Park
New Delhi
- (2) Mr. Pramod Kumar
Harry's Resturant
Shop No.4, 2nd Floor, Select City Walk Mall,
A-3 Distt Center, Saket, New Delhi-110017,

9/c

19/1/15
ADD(BLP)

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:-M/s Harry's Resturant(A Unit of Harry's India Private Ltd.)
Shop No-S-4, 2nd Floor, Select City Mall,A-3,Distt. Center Saket,
New Delhi-110017
 2. Type of occupancy:- Group – D, Assembly Building (Restaurant)
 3. Type of case:- New
 4. Details of previous NOC:- Nil
 5. Fire safety directives No.- Nil
 6. Date of inspection:-17/12/14
 7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
 8. Name & designation of officer From the building side:- Mr. Pramod Kumar (Manager)
 9. Year of construction:- 2007.
 - 10.Applicant's letter No:-No.DHO/SZ/2014/D/1674 dated 20/11/14
- Building is comprised of Basement, Ground + Two Upper Floors. Restaurant is running at second floor.

| Sl.No | Minimum Standards on fire Prevention and fire safety U/R 33 | Requirement NBC | Provided at site | Remarks MR/NMR |
|-------|---|-----------------|--|----------------|
| 1. | Access to Building | | | |
| | 1) Road width | 9mtrs | Provided | MR |
| | 2) Gate width | N/A | N/A | N/A |
| | 3) Width of internal road | 06 | Provided | MR |
| 2. | Number, Width Type & Arrangement of Exits | | Provided and maintained by Mall | |
| | A. Number of staircases | | | |
| | 1. Upper floors | 1.5m | Two nos. Provided near Restaurant | MR |
| | 2. Basements | N/A | N/A | N/A |
| | B. Width of staircase | | | |
| | 1. Upper floors | 1.5m | 1.52m & 1.16m | MR |
| | 2. Basements | N/A | N/A | N/A |
| | C. Protection of exits | | | |
| | 1. Fire check door | Required | Provided by mall | MR |
| | 2. Pressurization | Required | Provided by mall | MR |
| | D.No. of continuous staircase to terrace | Required | Provided by mall | MR |
| | E. Width of corridor | Required | Provided by mall | MR |
| | F. Door size | 02 m | 2 m & 0.90m | MR |
| 3. | Compartmentation | | Provided and maintained by Mall | |
| | 1) Fire check door | Required | Provided by Mall | MR |
| | 2) Sealing of electrical shafts | Required | Provided by Mall | MR |
| | 3) Fire rating of shaft door | Required | Provided by Mall | MR |
| | 4) Water curtain | Required | Provided by Mall | MR |
| | 5) Fire Dampers | Required | Provided by Mall | MR |
| 4. | Smoke Management System | | Provided and maintained by Mall | |
| | 1) Basements | 30 a/c per hour | Provided by Mall | MR |
| | 2) Upper floors | 12 a/c per hour | Provided by Mall | MR |
| 5. | Fire Extinguishers | | Provided and maintained by Mall | |
| | 1) Total numbers | | 06 Nos. | MR |
| | 2) Types | ISI Marked | ABC, Co2 ,Foam | MR |
| | 3) ISI marking | | Yes | MR |

| | | | | |
|------------|---|--|---------------------------------|----|
| 6. | First-Aid Hose Reel | Provided and maintained by Mall | | |
| | 1) Total number of each floor | Required | 01 no. provided near restaurant | MR |
| | 2) Length of hose reel hose | 30 m | Provided | MR |
| | 3) Nozzle diameter | 5mm | Provided | MR |
| 7. | Automatic Fire Detection & Alarming System | Provided and maintained by Mall | | |
| | 1) Type of detectors | Smoke | Provided by Mall | MR |
| | 2) Location of main panel | Fire control room | Provided by Mall | MR |
| | 3) Location of repeater panel | Every floor | Provided by Mall | MR |
| | 4) Alternate source of power | Required | Provided by Mall | MR |
| | 5) Hooter's Location | Every floor | Provided by Mall | MR |
| 8. | MOEFA | Provided and maintained by Mall | | |
| 9. | Public Address System | Provided and maintained by Mall | | |
| 10. | Automatic Sprinkler System | Provided and maintained by Mall | | |
| | 1) Basement | Required | Provided by Mall | MR |
| | 2) Upper floors | Required | Provided by Mall | MR |
| | 3) Sprinkler above false ceiling | Required | Provided by Mall | MR |
| 11. | Internal Hydrants | Provided and maintained by Mall | | |
| | 1) Size of riser/down-comer | 150mm | Provided by Mall | MR |
| | 2) Number of hydrants per floor | Required | Provided by Mall | MR |
| | 3) Hose box | Required | Provided by Mall | MR |
| 12. | Yard Hydrants | Provided and maintained by Mall | | |
| | 1) Total number of hydrants | Required | Provided by Mall | MR |
| | 2) Hose box | Required | Provided by Mall | MR |
| 13. | Pumping Arrangement | Provided and maintained by Mall | | |
| | 1) Ground level | | | |
| | a) Discharge of main pump | Required | Provided by Mall | MR |
| | b) Head of main pump | Required | Provided by Mall | MR |
| | c) Number of main pump | Required | Provided by Mall | MR |
| | d) Jockey pump out put | Required | Provided by Mall | MR |
| | e) Jockey pump head | Required | Provided by Mall | MR |
| | f) Stand by pump output | Required | Provided by Mall | MR |
| | g) Stand by pump head | Required | Provided by Mall | MR |
| | h) Auto starting/Manual stopping | Required | Provided by Mall | MR |
| | 2) Terrace level | | | |
| | a) Discharge of pump | Required | Provided by Mall | MR |
| | b) Head of pump | Required | Provided by Mall | MR |
| | c) Power supply | Required | Provided by Mall | MR |
| | d) Auto starting of pump | Required | Provided by Mall | MR |
| 14. | Captive Water Storage for Fire Fighting | Provided and maintained by Mall | | |
| | 1) Under ground tank capacity | Required | Provided by Mall | MR |
| | a) Draw-off connection | Required | Provided by Mall | MR |
| | b) Fire service inlet | Required | Provided by Mall | MR |
| | c) Access to tank | Required | Provided by Mall | MR |
| | d) Over head tank capacity | Required | Provided by Mall | MR |
| 15. | Exit Signage. | Provided and maintained by Mall | | |

| | | | | |
|-----|---|--|------------------|-----|
| 16. | Provision of Lifts. | Provided and maintained by Mall | | |
| | a) Pressurization of lift shaft | Required | Provided by Mall | MR |
| | b) Pressurization of lift lobby | Required | Provided by Mall | MR |
| | c) Communication in lift car | Required | Provided by Mall | MR |
| | d) Fireman's switch | Required | Provided by Mall | MR |
| | e) Lift signage | Required | Provided by Mall | MR |
| 17. | Stand by Power Supply | Provided and maintained by Mall | | |
| 18. | Refuge Area | Provided and maintained by Mall | | |
| | Total area | N/A | N/A | N/A |
| | location | N/A | N/A | N/A |
| 19. | Fire Control Room | Provided and maintained by Mall | | |
| | a) Detector system panel | Required | Provided by Mall | MR |
| | b) Flow switch panel | Required | Provided by Mall | MR |
| | c) PA system panel | Required | Provided by Mall | MR |
| | d) Battery backup | Required | Provided by Mall | MR |
| | e) Building floor plan | Required | Provided by Mall | MR |
| 20. | Special Fire Protection System for Protection of special Risk, if any: | | | |

The fire protection system provided in the restaurant were checked and found functional at the time of inspection.
 The mall has issued FSC vide letter no. F6/DFS/MS/2011/3114 dated 22/11/2011.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 3 5 of the Delhi Fire Service Rules 2010/-----

Accordingly DFA is put up please.

[Signature]
 18/12/14
 Signature of the inspecting officer
 Name :- D.B. Mukherjee.
 Designation :- Assistant Divisional Officer.

Do (Sign)

~~Signature~~

[Signature]
 27/11/14