

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/2015/W2/126

Dated: 27/01/2015

**FIRE SAFETY CERTIFICATE**

Certified that Himanshu Cosmetics, H-234, Sec-3, Bawana Industrial Area, Bawana Delhi-110039. Comprised of Basement + Ground + two upper floor owned / occupied by Himanshu Cosmetics was granted NOC by this department vide letter No. F5/(3A)/DFS/MS/2011/146 Dated: 06/06/2011. The premises was re-inspected by the officers concerned of this department on 10/12/2014 in the presence of Sh. Sanjay Kumar of the factory and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the Fire Safety Certificate is renewed and premises is fit for Class-G (G-II) Industrial with effect from 27 / 01 /2015 for a period of three years subject to conditions printed below.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 27/01/15 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Ph: 011-23414250

**Copy to:**

1. Himanshu Cosmetics, H-234, Sec-3, Bawana Industrial Area, Bawana Delhi-110039.
2. The Assistant Drugs Controller & Licensing Authority, Govt. of NCT of Delhi, F-17, Karkardooma, New Delhi-110032

**INSPECTION REPORT**

1. Name & address of the building : Himanshu Cosmetics, H-234, Sec-3, DSIDC Bawana, Delhi  
 2. Type of Occupancy : Industrial G-2 (B + G + 2 Upper Floor)  
 3. Type of Case : New Case / *Renewal.* ✓  
 4. Details of previous NOC : Letter No. F5/(3A)/DFS/MS/2011/146 Dated: 06/06/2011  
 5. Fire Safety directives letter No : NBC  
 6. Date of inspection : 10/12/2014  
 7. Name of the Inspecting Officers : DO (NW)  
 8. Name and designation of officers  
 from the building side : Sh. SANJAY KUMAR  
 9. Year of Construction : 2010-11  
 10. Applicant's letter No. : L. No nil dated 25/11/2014  
 Covered area 250 sq. mtr

S.No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	M.R. ✓
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	Old case	Old case	Old case ✓
	• Basements	Old case	Old case	Old case ✓
	b. Width of staircases			
	• Upper Floors	Old case	Old case	Old case ✓
	• Basements	Old case	Old case	Old case ✓
	c. Protection of exits			
	Fire check door	—	—	—
	Pressurization			
	e. No. of continuous staircases to terrace	—	—	—
		One	One	M/R ✓
	g. Width of Corridor	—	—	—
	h. Door Size	1 mtr	P	M/R ✓
3	<b>Compartmentation.</b>			
	• Fire check door	N.A	N.A	N.A ✓



	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	R	Exhaust fan provided	M.R
		30 a/c per hour	Exhaust fan provided	M.R
		12 a/c per hour		
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	One @ 300 mtr	P	M.R.
		ABC	P	M.R.
		ISI marked	P	M.R.
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	One	Provided on each floor	M.R.
		30mm	P	M.R.
		5mm	P	M.R.
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
8	MOEFA	N.A	N.A	N.A
9	Public Address System.	R	P	M.R
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	R	P	M.R
		R	P	M.R
		—	—	—
11	<b>Internal Hydrants</b>			

	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	N.A	N.A	N.A
		N.A	N.A	N.A
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level                             <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level                             <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>			
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		900 LPM	P	MR
		40 m	P	MR
		R	P	M.R
		R	P	M.R
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity                             <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>• Overhead Tank capacity</li> </ul>	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		10,000 ltrs.	P	MR
15	<b>Exit Signage.</b>	R	P	MR



N-7

Himanshu Cosmetics, H-234, Sec-3, DSIDC Bawana, Delhi-110039

16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N.A	N.A	N.A
	• Pressurization of Lift lobby	N.A	N.A	N.A
	• Communication In lift Car	N.A	N.A	N.A
	• Fireman's Grounding Switch	N.A	N.A	N.A
	• Lift Signage	N.A	N.A	N.A
17	<b>Standby power supply</b>			
18	<b>Refuge Area.</b>			
	➤ Total Area	N.A	N.A	N.A
	➤ Location	N.A	N.A	N.A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N.A	N.A	N.A
	• Flow Switch Panel	N.A	N.A	N.A
	• PA System Panel	N.A	N.A	N.A
	• Batter backup	N.A	N.A	N.A
	• Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection Systems for Protection of special Risks, if any:	--	Nil	--

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no **F5/(3A)/DFS/MS/2011/146 Dated: 06/06/2011** Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation



*Do (NW) on leave*

*Do (NW)*

*29/12/14*