

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/2015/ school/wz/115

Dated: 23/01/2015

FIRE SAFETY CERTIFICATE

Certified that Nigam Pratibha Vidyalaya, Khyber Pass, Delhi-110054 comprised of Ground Floor only owned/occupied by Nigam Pratibha Vidyalaya has already been issued fire safety certificate vide letter no. F-6/DFS/MS/2008/1001 dated 09/11/2008. For M C Primary Co-ed School. The premises was re-inspected by the officer from this department on dated 22/12/2014 in the presence of Smt. Krishna (Principal) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of Circular dated 17/01/2005 issued by Director of Education and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 23/01/2015 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 23/01/15 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, Nigam Pratibha Vidyalaya, Khyber Pass, Delhi-110054
2. The Dy. Director of Education, NDMC Civil Line Zone, 5th floor Rajpur Road, Delhi 54

INSPECTION REPORT

Gr. floor only

Previous name - M.C. Pky. Co. Ed. School - Khyber Pass

present - Hargam Pratibha Vidyalyaya, Khyber Pass

1. Name & address of the building:
2. Type of Occupancy : *Educational*
3. Type of Case : New Case / Renewal
4. Details of previous NOC : *F-6/DPS/MS/2008/1001* dt. *9.11.08*
5. Fire Safety directives letter No : *Dir of Edu. CR - 17.01.05*
6. Date of inspection : *22.12.14*
7. Name of the Inspecting Officers : *AO (B.W)*
8. Name and designation of officers
from the building side : *Smt. Krishna Principal*
9. Year of Construction : *1989*
10. Applicant's letter No. : *D/S.309/DDE/CLZ/2014* dt. *7.10.14*

Plot area:- *3000 m²* Covered area:- *500 m²* No.'s of students:- *325* No.'s of classrooms:- *6*
to 3 room for other purpose

	Minimum Standards on fire prevention and fire safety U/R 33	Circular Dir. of Edu Requirement/ NBC	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p><i>Accessible</i></p> <p><i>- do</i></p> <p><i>-</i></p>	<p><i>Accessible</i></p> <p><i>- do</i></p> <p><i>-</i></p>	<p><i>MR ✓</i></p> <p><i>MR ✓</i></p> <p><i>-</i></p>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 			
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 			
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	<i>old case</i>	<i>old case double doors</i>	<i>old case</i>

N/A

3	Compartmentation.				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 				
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour			
		12 a/c per hour			
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	3 ABC	3	MR	✓
		ISI marked	ABC	MR	✓
			yes	MR	✓
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m			
		5 mm			
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 				
8	MOEFA				
9	Public Address System.				
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 				
11	Internal Hydrants				
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 				

12	Yard Hydrants.			
	<ul style="list-style-type: none">Total number of hydrantsHose Box			
13	Pumping Arrangements.			
	<ul style="list-style-type: none">Ground Level<ul style="list-style-type: none">Discharge of main PumpHead of Main pumpNumber of main pumpsJockey Pump out putJockey pump headStandby Pump out putStandby Pump HeadAuto Starting/ Manual stoppingPump House AccessTerrace level<ul style="list-style-type: none">Discharge of pumpHead of the pumpPower SupplyAuto Starting of pump			
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none">Underground tank capacity<ul style="list-style-type: none">Draw-off connectionFire service inletAccess to tankOverhead Tank capacity			
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none">Pressurization of Lift ShaftPressurization of Lift lobbyCommunication In lift CarFireman's Grounding SwitchLift Signage			
17	Standby power supply			

N-8

18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

- Note:-**General requirements for school as per Director of Education Circular dated 17/01/05
- Escape route..... clear
 - LPG cylinders in laboratories..... No
 - Electric wiring conduit pipes..... MCB and ELCB..... ✓ ✓
 - Electric meter board..... not below s/c
 - Basement use as per BBL 1983..... N/A
 - Emergency telephone no. board..... displayed
 - Generator set..... No

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no F.E./D.P.S./M.S./2000/1001 dated 09/11/08 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Mh Sharma
28-12-14

Designation

Designation

DO (W) Quish

ADD (W)