

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001


NO. F6/DFS/MS/School/2015/ SZ/ 130

DATED: 28/1/15

FIRE SAFETY CERTIFICATE

Certified that the Parkash Public School, Sector-7, Pocket-2, Dwarka, New Delhi-110045, comprised of ground plus two upper floors was granted NOC by this department vide letter no. F6/MS/DFS/2012/School/603 dated 23.2.2012. The premises was re-inspected by the officer concerned of this department on 21.1.2015 in the presence of Sh. Komal Vats (owner) and found that the above said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi Letter No: Estate/CC/Fire Safety/2011/3298 Dtd. 01.03.2011 and that the premises / building is fit for occupancy of class B "Educational Building" with effect from 28/1/15 for a period of **three years** for ground plus three upper floors in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on28/1/15..... at New Delhi by



(Dr. GC Misra)
Chief Fire Officer
Ph.011-23414333

o/a

Copy to:

- 1 Dy. Director, (Education) GNCT of Delhi, Old Secretariat, New Delhi-110054.
- 2 Manager, Parkash Public School, Sector-7, Pocket-2, Dwarka, New Delhi-110045.

N/A

INSPECTION REPORT

1	Name & address of the building	Parkash Public School, Sector-7, Pocket-2, Dwarka, New Delhi-110045.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/MS/DFS/2012/603 dated 23.2.2012		
5	Fire safety directives letter No	Directorate of Education: F/16/Estate/CC/fire Safety/2011/3298-3398, Dated 1.3.2011		
6	Date of inspection	21.2.2015		
7	Name of the inspecting Officers	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Komal Vats (owner)		
9	Year of construction	2007, 2014. <i>dy</i>		
10	Applicant's letter No.	Nil dated 4.8.2014 <i>dy</i>	(ground plus three upper floors)	
		Earlier Ground Plus Two Upper floors, management have constructed one more upper floor Now G+3 upper floors		
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Accessible	12 Mtrs.	MR
	2) Gate width	Approachable	4.50 Mtrs.	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs.	1.54, 1.22 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	2 Nos.	MR
	e. Width of corridor	1.86 to 2.36 Mtrs.	1.86 to 2.36 Mtrs.	MR
	f. Door size	1 Mtr.	1.12 to 2.04 Mtrs.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement		N/A	N/A
	upper floors	12 ac charge	Natural Vent.	MR
5	Fire Extinguishers			
	total numbers	2 Nos. each floor	9 Nos.	MR
	Types	ABC ISI Marked	ABC	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	1 No.	1 No.	MR
	Length of Hose reel hose	30 m	30 Mtrs.	MR
	Nozzle Diameter	5 mm	5 mm.	MR
7	P			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	Old case	75MM	MR
	Number of Hydrants per floor	N/A	1 No.	MR
	hose Box	N/A	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	Old Case	450 & 180 LPM	MR
	b. head of the pump	Old Case	40 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	MR
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	Old Case	5000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	Co2 & ABC		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, renewal of FSC issued vide letter no.F6/DFS/MS/School/2012/603 is recommended for ground plus three upper floors under rules 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval and signature please.


Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)