

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110 001

No. *F6/DFS/MS/2015/52/110*

Dated: *22/01/15*

FIRE SAFETY CERTIFICATE

Certified that R.B.Culture Centre/Ceremonial Hall adjacent to Auditorium Building at Rastrapati Bhavan, New Delhi, comprised of ground floor (hall) plus one upper floor (first floor only AHU), have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules,2010 and verified by the officer concerned of this department on 19-01-2015 in the presence of Sh. Sarabh Kumar (Executive Engineer) and found that the said premises is fit for occupancy class "Assembly" at ground floor only with effect from *22/01/2015* for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued *22/01/2015* at New Delhi by



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333

Copy to:-

Sh. Sarabh Kumar (Executive Engineer), Electric,
President Estate, Electric Division, CPWD,
Rastrapati Bhawan, New Delhi-110004.

Conditions for the validity of fire safety certificate are overleaf:-

gic
h

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : RB Culture Centre/Ceremonial Hall located adjacent to Auditorium building, Rashtrapati Bhavan, New Delhi-110004.
2. Building is comprised of : Ground plus one floor.(Culture centre at ground floor & only AHU at First floor.
3. Type of Occupancy : Assembly Building (Culture Centre/Ceremonial Hall).
4. Type of Case : New Case
5. Details of Previous NOC : Nil.
6. Fire Safety direction letter No : No.F6/DFS/MS/BP/2011/2226, Dated 13.09.2011.
7. Date of Inspection : 19.01.2015
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of officer from the building side : Sh. Saurbh Kumar (Executive Engineer).
10. Year of Construction : 2014.
11. Applicant's letter No. : DB-17(Ceremonial Hall)/RSVM/2014-15/218, Dated 16.01.15.

S.N	Minimum Standards on fire prevention and fire safety U/R33	Requirements as Per Directives.	Provided at Site	Remarks
1	Access to building			
	Road width	9m	9 m	MR
	Gate width	6m	Directly approachable On road.	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	02nos. for AHU rooms at 1 st floor.	02nos for AHU rooms from Auditorium building both Buildings interconnected.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	1.25m	1.25m	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace.	N.A.	N.A.	N.A.
g. Width of Corridor	01no.	01no.	NMR	
h. Door Size				
	N.A.	N.A.	N.A.	
	1.5m	1.65m	MR	
3	Compartmentation			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A	N.A
	Upper floor	12 a/c per	Provided	MR

Ceremonial Hall Adjoining Auditorium President Estate R.P. Bhawan

5.	Fire Extinguisher			
	Total numbers	8 nos.	12 nos.	MR
	types	WCO ₂ & ABC	WCO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of hall floor	02nos.	04nos.	MR
	Length of hose reel hose	30 m	30m	MR
	Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Heat & Smoke	Heat & Smoke	MR
	Location of main panel	Ground floor	Ground Floor	MR
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	Required	Provided	MR
	Hooters	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	Required	Provided	MR
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100	100mm	MR
	Number of hydrants in hall floor	02nos.	04nos.	MR
	Hose Box	Required	04 nos. Provided	MR
12	Yard Hydrants.			
	Total number of hydrants	04nos.	04nos.	MR
	Hose Box	04nos.	04nos.	MR
13	Pumping Arrangements.			
	• Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	2850LPM	2850LPM	MR
	➤ Head of Main Pump	70m	70m	MR
	➤ Number of main pumps	02Nos.	02Nos.	MR
	➤ Jockey pump out put	180&280LPM	180 &280LPM	MR
	➤ Jockey pump head	70m(Each)	70m(Each)	MR
	➤ Standby pump out put	2850LPM.	2850LPM	MR
	➤ Standby pump Head	70m	70m	MR
	➤ Auto Starting /Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 LPM	450LPM	MR
	➤ Head of the Pump	40 Mtrs.	40Mtrs.	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

Ceremonial Hall Adjoining Auditorium President Estate R.F. Bhawan, N.D.

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	50000Liters.	200000Liters.	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	5000Ltrs.	5000Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	Required	Provided	MR
	Firemen's grounding switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided D.G. Set	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer

Name Vedpal

Designation ADO

D.O. (South)

(Handwritten signature and date)
21/1/15

(Handwritten signature and date)
21/1/15