

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/2015 / 42/107

Dated: 22 / 01 / 2015

FIRE SAFETY CERTIFICATE

Certified that Dee Pearls Banquet Hall, located at 2nd Floor, D Mall, Sector- 10, Rohini, Delhi owned / occupied by Sh Rajiv Chawla have complied with the fire prevention and fire safety Requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 31/10/2014 in the presence of Sh Rajiv Chawla and that the building / premises is fit for occupancy **Class Sub Div. D-5 Assembly Buildings** with effect 22 / 01 / 2015 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
2. The fire suppression / protection arrangements provided are to minimize losses, if maintained in good working condition. These systems cannot give a guarantee that there will be no fire or losses in the event of one.
3. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
4. This report may not in any way be treated as regularization of unauthorized construction, if any. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The trained fire fighting staff should be available round the clock.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 22 / 01 / 2015 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250



Copy to:

1. The Dy. Health Officer, Rohini Zone, Health Department, Sector – 5 Rohini, Delhi 110085
2. Sh Rajiv Chawla, Dee Pearls Banquet Hall, 2nd Floor, D Mall, Sector- 10, Rohini, Delhi.

INSPECTION REPORT**Located on 2nd Floor of "D" Mall, Sector- 10, Rohini.**

1. Name & address of the building : Dee Pearls Banquet hall, 2nd floor, D Mall Sector 10, Rohini
2. Type of Occupancy : **Banquet Hall**
3. Type of Case : New Case
4. Details of previous NOC : **F6/DFS/MS/2014/WZ/360 dated 14/03/2014 (Mall)**
5. Fire Safety directives letter No : -----
6. Date of inspection : 31/10/2014
7. Name of the Inspecting Officers : DCFO (WZ) & DO (NW)
8. Name and designation of officers
from the building side : Sh. Rajiv Chawla
9. Year of Construction : 2006 (As per Mall)
10. Applicant's letter No.: : DHO/RZ/2014/2244 date 20/01/2014

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks/ NMR
1	Access to building			
	• Road width	6 mtr	45 mtr	M.R
	• Gate width	5 mtr	No main Gate provided	M.R
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04	04	M.R
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	1.5 mtr	Provided with Mall	M.R
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	R	P	M.R
	• Pressurization	R	Common with Mall	M.R
	e. No. of continuous staircases to terrace	04	04	M.R
	g. Width of Corridor	--	--	--
	h. Door Size	2 mtr x 2	P	M/R
3	Compartmentation.			
	• Fire check door	R	P	M/R

N-4

Dee Pearls Banquet hall, 2nd floor, D Mall Sector 10, Rohini

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	R	P	M/R
		R	P	M/R
		--	--	--
		--	--	--
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour	P	M/R
		12 a/c per hour	P	M.R
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	One @ 300 m ²	20	M.R
		20	ABC / Co2	M.R
		ISI marked	YES	M.R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hoe reel hose Nozzle diameter 	Two @ each floor	Common with Mall	M.R
			P	M.R
		30 m	P	M.R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke/Heat	Provided in Banquet & Mall	M.R
		GF	P	M.R
		N/A	N/A	N/A
		R	P	M.R
		At strategic locations	P	M.R
8	MOEFA	R	P	M.R
9	Public Address System.	R	P	M.R
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	R	P	M.R
		R	P	M.R
		R	P	M.R
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	6''	Common with Mall	M.R
		02	Common with Mall	M.R
		02	Common with Mall	M.R

1
114

2/5

Dee Pearls Banquet hall, 2nd floor, D Mall Sector 10, Rohini

12	Yard Hydrants.			
	• Total number of hydrants	N.A	Provided with Mall	N.A ✓
	• Hose Box	N.A	Provided with Mall	N.A ✓
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	2850LPM	Common with Mall	M.R ✓
	➤ Head of Main pump	70 m	Common with Mall	M.R ✓
	➤ Number of main pumps	2	Common with Mall	M.R ✓
	➤ Jockey Pump out put	180 LPM	Common with Mall	M.R ✓
	➤ Jockey pump head	70 m	Common with Mall	M.R ✓
	➤ Standby Pump out put	2850 LPM	Common with Mall	M.R ✓
	➤ Standby Pump Head	70 m	Common with Mall	M.R ✓
	➤ Auto Starting/ Manual stopping	R	Common with Mall	M.R ✓
	➤ Pump House Access	R	Common with Mall	M.R ✓
	• Terrace level			
	➤ Discharge of pump	—	—	—
	➤ Head of the pump	—	—	—
	➤ Power Supply	—	—	—
	➤ Auto Starting of pump			
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	2,00,000 ltr	Common with Mall	M.R ✓
	➤ Draw-off connection	R	Common with Mall	M.R ✓
	➤ Fire service inlet	R	Common with Mall	M.R ✓
	➤ Access to tank	R	Common with Mall	M.R ✓
	• Overhead Tank capacity	20,000 ltr	Common with Mall	M.R ✓
15	Exit Signage.	R	P	M.R ✓
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	R	P	M.R ✓
	• Pressurization of Lift lobby	R	P	M.R ✓
	• Communication In lift Car	R	P	M.R ✓
	• Fireman's Grounding Switch	R	P	M.R ✓
	• Lift Signage	R	P	M.R ✓
17	Standby power supply	R	Common with Mall	M.R ✓

2/6

Dee Pearls Banquet hall, 2nd floor, D Mall Sector 10, Rohini

18	Refuge Area.			
	➤ Total Area	N.A	N.A	N.A
	➤ Location	N.A	N.A	N.A
19	Fire Control Room			
	• Detector System Panel	R	Common with Mall	M.R
	• Flow Switch Panel	R	Common with Mall	M.R
	• PA System Panel	R	Common with Mall	M.R
	• Batter backup	R	Common with Mall	M.R
	• Building Floor Plans	R	Common with Mall	M.R
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer *Kentat 07/11*

Name

Designation *DeFO (w2)*

Signature of the Inspecting Officer *[Signature]*

Name

Designation *12/11/14 DO (nw)*