

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/School/2015/02/118

Dated: 23/01/2015

FIRE SAFETY CERTIFICATE

Certified that the Shiv Shakti Education Society (Regd.) Prestige Convent Sr. Sec. School B- 5, Sector-8, Rohini, Delhi-110085 comprised of Ground + Three upper floor owned / occupied by Prestige Convent Sr. Sec. School has already been issued fire safety certificate vide letter no.F-6/DFS/MS/2011/1368 dated 14/07/2011. The premises was re-inspected by the officer from this department on dated 29/12/2014 in the presence of Mrs. Mona Singh (Principal) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011/NBC Part IV and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 23 / 01 /2015 for a period of three years, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 23/01/15 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Ph: 011-23414250  
*d/c*

**Copy to:**

- 1 The Principal, Shiv Shakti Education Society (Regd.) Prestige Convent Sr. Sec School B- 5, Sector-8, Rohini, Delhi-110085
- 2 The Director of Education, Old Secretariat, Delhi

92.7 540000

### INSPECTION REPORT

1. Name & address of the building : Prestige Convent School, Pkt-B-5 Sec-8
2. Type of Occupancy : Educational Rohini Delhi-85
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No F-6/DFS/MS/2011/1368 Dated: 14.7.11
5. Fire Safety directives letter No : NBC Part IV
6. Date of inspection : 29.12.14
7. Name of the Inspecting Officers : AOO (BWS)
8. Name and designation of officers from the building side : Mrs. Mona Singh, Principal
9. Year of Construction : 2002
10. Applicant's letter No. : NIL Dt. 11.12.14

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu/ NBC	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	<u>Accessable</u>	<u>Accessable</u>	<u>MR</u> ✓
	• Gate width	<u>do</u>	<u>do</u>	<u>MR</u> ✓
	• Width of internal road	<u>do</u>	<u>do</u>	<u>MR</u> ✓
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	<u>—</u>	<u>—</u>	<u>—</u>
	• Upper Floors	<u>01</u>	<u>02</u>	<u>MR</u> ✓
	• Basements	<u>—</u>	<u>—</u>	<u>—</u>
	b. Width of staircases	<u>—</u>	<u>—</u>	<u>—</u>
	• Upper Floors	<u>1.50M<sup>2</sup></u>	<u>1.50M<sup>2</sup> each</u>	<u>MR</u> ✓
	• Basements	<u>—</u>	<u>—</u>	<u>—</u>
	c. Protection of exits	<u>—</u>	<u>—</u>	<u>—</u>
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• Pressurization	<u>—</u>	<u>—</u>	<u>—</u>
	e. No. of continuous staircases to terrace	<u>R</u>	<u>P</u>	<u>MR</u> ✓
	g. Width of Corridor	<u>—</u>	<u>—</u>	<u>—</u>
	h. Door Size	<u>—</u>	<u>—</u>	<u>—</u>
		<u>1.00M<sup>2</sup></u>	<u>1.00M<sup>2</sup> D.D.</u>	<u>MR</u> ✓
3	<b>Compartmentation.</b>			
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• Sealing of electrical shafts	<u>—</u>	<u>—</u>	<u>—</u>



12	<b>Yard Hydrants.</b> <ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>			
13	<b>Pumping Arrangements.</b> <ul style="list-style-type: none"> <li>Ground Level           <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level           <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	<p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p>
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity           <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	<p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p>	<p style="text-align: center;">N/A</p>
15	<b>Exit Signage.</b>	R	P	MR
16	<b>Provision of Lifts.</b> <ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>			
17	<b>Standby power supply</b>	NR	P 125 kVA	-

N/10

18	<b>Refuge Area.</b>			
	➤ Total Area			
	➤ Location			
19	<b>Fire Control Room</b>			
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

N/A

**Note:-**General requirements for school as per Director of Education Circular dated. 4.1.03.../2011.

- Escape route..... clear
- LPG cylinders in laboratories..... used in chem. lab - LPG cy. stored on roof.
- Electric wiring ..... concealed MCB and ELCB provided
- Electric circuit.....
- Electric meter board ..... below s/c but covered with metallic box.
- Basement use as per BBL 1983..... N/A
- Emergency telephone no. board..... displayed
- Generator set..... 1.25 KVA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/2.E.9/45/2011/1368 dated 14.7.11 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

*[Handwritten signature]*  
DO (2/11)

*[Handwritten signature]*  
11/11/15  
A20/BW