

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/school/2015/W2/98

Dated: 20/01/15

FIRE SAFETY CERTIFICATE

Certified that the **Vijay Public School** located at **Ground Floor** only at **51-A, Inderlok, Delhi - 110035** of a premises comprised of Ground + 02 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2012/121 Dated 13-01-2012. The premises was re inspected by the officers concerned of this department on 24-12-2014 in the presence of Sh. Savitri Rawat (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298-3398 Dated 01-03-2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 20/01/15 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/01/15 at New Delhi by.

(Santokh Singh)
Chief Fire Officer,
Ph: 011 - 23414250.

el/b

Copy to:

1. The Principal, Vijay Public School, Ground Floor 51-A, Inderlok, Delhi - 35

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The 1st & 2nd Floors shall be not used strictly for school activities or other hazardous activities.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Vijay Public School,51-A,Inderlok, Delhi-35
2. Type of Occupancy : Educational (School running at Ground Floor in a building comprising Ground + 2 Upper Floor, 1st & 2nd Floors are being used for storage of old furniture, household etc)
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/School/2012/121 dated 13/01/2012
5. Fire Safety directives Letter No. : 3298-3398 dated 01-03-2011
6. Date of inspection : 24-12-2014
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer
from the building side : Smt Savitri Rawat(Principal)
9. Year of Construction : 1990
10. Applicant's letter No. : Form J Dated 28/11/2014

Plot Area - 180 M²
 Covered Area -180 M²
 No. or Class Rooms-4
 No. of Student- 120

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases	NA		
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1mtr	Provided 2X1mtr(Rooms having>45 students)	MR

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	02nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose		NA	NA
	• Nozzle diameter	30m	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box			
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			


20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

Note:-General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape routeClear.....
2. LPG cylinders in laboratories ; NA.
3. Electric wiring ...Conduit Wiring..... MCB and ELCB ... Provided.
Electric circuit
4. Electric meter boardNot under the staircase.....
5. Basement use as per BBL 1983 ... NA
6. Emergency telephone no. board Displayed.....
7. Generator set ...NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as Nil noted at serial numbers

Signature of the Inspecting Officer

 Officer

Signature of the Inspecting

Name

Uday Vir Singh

Name

Designation

HSO/wp

Designation