

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No. F6/DFS/MS/GH/2015/ 1402/175

Dated 06/02/15

FIRE SAFETY CERTIFICATE

Certified that the **Annapurna Guest House** located at **680, Church Mission Road, Fatehpuri, Delhi** comprises of **Ground floor + 4 upper floors (Ground floor - commercial use, 1st Floor -Dinning hall, 2nd Floor - Reception & 03 guest rooms, 3rd Floor -03 guest rooms & 4th Floor -01 Generator room & 01 store room)** was granted NOC by this department vide letter No.F6/MS/DFS/GH/2012/426 dated 07-02-2012. The premises was re-inspected by the officer concerned of this department on 15-01-2015 in the presence of **Mr. Sanjeev Soni (Owner)** and found that the said guest house building have **added 02 more rooms at 4th floor now no. of rooms floor wise will be (Ground floor - commercial use, 1st Floor -Dinning hall, 2nd Floor - Reception & 03 guest rooms, 3rd Floor - 03 guest rooms & 4th Floor -02 guest rooms i.e. total 08 guest rooms & 01 dinning hall).** and have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential Group A-1 for 01 dinning hall at first floor, 03 guest rooms at 2nd floor, 03 guest rooms at 3rd floor and 02 guest rooms at 4th floor** with effect from ~~06/02/15~~ 2015 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...~~06/02/15~~..... at New Delhi by.

(Dr. G.C.Misra)

Chief Fire Officer

Ph - 011-23414333

Copy to:-

1. Mr Sanjeev Soni, Annapurna Guest House, 680, Church Mission Road, Fatehpuri, Delhi
2. The Addl. Commissioner of police (Lic), 1st floor, P S Defence colony, New Delhi for information letter No. 46410/Joint C.P./Lic.(H) dated 24/12/2014.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building:- Annapurna Guest House located at 680, Church Mission Road, Fatehpuri, Delhi
2. Type of occupancy:- Residential Group A-1
Ground +4 Upper Floors.(08 guest rooms)
3. Type of case:- Renewal
4. Details of previous NOC:- No. F6/MS/DFS/GH/2012426 dated 07.02.2012
5. Fire safety directives No.- N/A
6. Date of inspection:- 19/01/15
7. Name of the inspecting officer:- D.O. Gurmukh Singh, ADO Rajesh Kumar
8. Name & designation of officer
From the building side:- Mr. Sanjeev Soni (Owner)
9. Year of construction:- Old.
10. Applicant's letter No:- 46410/Joint.C.P/Lic. Dated 24/12/2014
Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33.	Requirement	Provided at site/PSS Area	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	06 M	MR
	2) Gate width	N/A	N/A	N/A
	3)Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 No	01 No.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	80 cm.	80 to 85 cms.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D.No. of continuous staircase to terrace	01 No	01 No	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			

	1) Total numbers	06 Nos.	06 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2 & W.CO2	MR
	3) ISI marking	ISI	Yes	MR
6.	First-Aid Hose Reel			MR
	1) Total number of each floor	01 no	01 at 1 st floor & 01 at 3 rd floor	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MÔEFA	N/A	N/A	MR
9.	Public Address System	Required	Provided	
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A

13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	225 lpm	225 LPM	MR
	b) Head of pump	40 m	40 m	MR
	c) Power supply	Required	Provided	MR

M/S

	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	NA	NA	NA
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	2,500 Ltrs.	2,500 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the guest house were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No.F6/MS/DFS/MS/2012/426 dated 07/02/2012, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Gurmukh Singh

[Signature]
27/1/15

Rajesh Kumar

[Signature]
27/1/15