

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/2015/Club/145

Dated: 02/02/15

FIRE SAFETY CERTIFICATE

Certified that the Delhi Flying Club Ltd. Safdarjang Airport, New Delhi-110003, comprised of ground floor only owned/Occupied by Delhi Flying Club Ltd. was granted NOC by this department vide letter No. F6/DFS/MS/2011/771, dated 27-04-2011. The premises was re-inspected by the officer concerned of this department on 20-01-2015 in the presence of Sh. Narender Saxena (Guest Relation Officer) and found that the said club building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class Assembly (Club Building) with effect from ... 02/02/2015 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 02/02/2015 at New Delhi by.



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333

o/c
h

Copy to:-,

Sh. Narender Saxena (Guest Relation Officer),

Delhi Flying Club Ltd. Safdarjang Airport, New Delhi-110003.

Conditions for the validity of fire safety certificate are overleaf:-

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : The Delhi Flying Club Ltd. Safdarjang Airport, New Delhi-110003.
2. Building comprises of : Ground floor only.
3. Type of Occupancy : Assembly (Club Building).
4. Type of Case : Renewal.
5. Details of Previous NOC : No.F6/DFS/MS/2011/771, Dated 27.04.2011.
6. Fire Safety direction letter No : No.F6/DFS/2006/1382, Dated 23.06.2006.
7. Date of Inspection : 20.01.15
8. Name of the Inspecting Officers: : Vedpal (ADO).
9. Name and designation of Officer from the building side : Sh. Narender Saxena(Guest Relation Officer).
10. Year of Construction : 2005
11. Applicant's letter No : No.DFC-58/DFC/06-07, dated 19.12.14.

S.No	Minimum Standards on fire prevention and fire safety under Rule33.	Requirement (Old NOC)	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	9m	MR
	Gate width	5m	Direct access on road	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases	.		
	Upper Floor	N.A.	N.A.	N.A.
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases	.		
	Upper Floor	N.A.	N.A.	N.A.
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	g. Width of Corridor	2 m	2 m	MR
	h. Door Size	1.5 m	1.5m	MR
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	15 a/c per hour	Exhaust fans Provided	MR


5.	Fire Extinguisher			
	Total numbers	12 nos.	12nos.	MR
	Types	ABC&WCO ₂	ABC&WCO ₂	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of ground floor	03nos.	03nos.	MR.
	Length of hose reel hose	30m	30m	MR.
	Nozzle diameter	5cm	5cm	MR.
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	Required	Provided	M R
9	Public address System.	Required	Provided	M R
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	➤ Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	450lpm	450lpm	MR
	➤ Head of Main Pump	40m	40m	MR
	➤ Number of main pumps	01no.	01no.	MR
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	Required	Provided	MR
	➤ Pump House Access	N.A.	N.A.	N.A.
	➤ Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.


The Delhi Flying Club Ltd. Safdarjang Airport, New Delhi-110003.

14	Captive Water Storage for Fire Fighting.			
	On ground level tank capacity	15000Liters	Provided	MR
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.	Required	Adequate	M R
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	Provided	M R
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Battery backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/DFS/MS/2011/771, dated 27.04.2011 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended. Shortcomings communicated vide this office letter dated 20.11.2014 has been rectified.

Accordingly DFA is put up for kind consideration please.

 21/11/15

 21/11/15
Signature of the Inspecting Officer

Name :Vedpal

Designation: Assistant Divisional Officer