

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/2015/W2/157

Dated: 03/02/2015

FIRE SAFETY CERTIFICATE

Certified that M/S G R D Cosmetics Industries, M-46, Sector-2, Bawana Industrial Area, Bawana Delhi-110039 located at Ground + One Upper Floor of a premise comprised of Basement + Ground + One Upper Floor owned / occupied by M/S G R D Cosmetics Industries was granted NOC by this department vide letter no. F6/DFS/MS/2012/88 Dated 10/01/2012. The premise was re-inspected by the officers concerned of this department on 05/01/2015 in the presence of Sh. Harpreet Singh of the factory and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the Fire Safety Certificate is renewed and premises is fit for Class Industrial Building (G-2) Class with effect from 03/02/2015 for a period of three years subject to conditions printed below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. **The basement shall be used strictly as per the provision of building bye laws.**
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 03/02/15 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. M/S G R D Cosmetics Industries, M-46, Sector-2, Bawana Industrial Area, Bawana Delhi-110039
2. The Assistant Drugs Controller & Licensing Authority, Govt of National Capital Territory of Delhi, F-17, Karkardooma, New Delhi-110032

INSPECTION REPORT

**(B + G + One upper Floors)
Basement used for storage only.
Ground and first for cosmetic.**

1. Name & address of the building : G. R. D Cosmetics, M-46, Sec-02, Bawana Industrial Area,
Bawana Delhi-110039.
2. Type of Occupancy : Industrial G-2
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F6/DFS/MS/2012/88 Dated – 10/01/2012
5. Fire Safety directives letter No : Nil
6. Date of inspection : 05 / 01 / 2015
7. Name of the Inspecting Officers : Do (NW) S.S. Tuli
8. Name and designation of officers
from the building side : Harpreet Singh
9. Year of Construction : 2011
10. Applicant's letter No. : Nil Dated 11/12/2014

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible	Accessible	M/R
		Accessible	Accessible	M/R
		--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	01	01	M/R
	<ul style="list-style-type: none"> • Upper Floors • Basements 	01	01	M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	125 cm	125 cm	M/R
		125 cm	125 cm	M/R
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	--	--	--
		--	--	--
	e. No. of continuous staircases to terrace	01	01	M/R
	g. Width of Corridor	1.5 mtr	1.5 mtr	M/R
	h. Door Size	100 cm	110 cm	M/R

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		--	--	--
		--	--	--
		--	--	--
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N/A N/A	N/A N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	08 ISI marked	08 ABC P	M/R M/R M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 @ at each floor 30 m 5 mm	02 Provided P P	M/R M/R M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A -- -- -- --	N/A -- -- -- --	N/A -- -- -- --
8	MOEFA	R	P	M/R
9	Public Address System.	R	P	M/R
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	R R --	P P --	M/R M/R --
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	N/A -- --	N/A -- --	N/A -- --

12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	--	--	--
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	--	--	--
	➤ Head of Main pump	--	--	--
	➤ Number of main pumps	--	--	--
	➤ Jockey Pump out put	--	--	--
	➤ Jockey pump head	--	--	--
	➤ Standby Pump out put	--	--	--
	➤ Standby Pump Head	--	--	--
	➤ Auto Starting/ Manual stopping	--	--	--
	➤ Pump House Access	--	--	--
	• Terrace level			
	➤ Discharge of pump	900 LPM	P	M/R
	➤ Head of the pump	40 m	P	M/R
	➤ Power Supply	--	--	--
	➤ Auto Starting of pump	--	--	--
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	--	--	--
	➤ Draw-off connection	--	--	--
	➤ Fire service inlet	--	--	--
	➤ Access to tank	10,000 Ltr	P	M/R
15	Exit Signage.	R	P	M/R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	--	--	--
	• Communication In lift Car	--	--	--
	• Fireman's Grounding Switch	--	--	--

	• Lift Signage	--	--	--
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	—	—	—
19	Fire Control Room			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F6/DFS/MS/2012/88**

Dated – 10/01/2012 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Handwritten signature and designation

Signature of the Inspecting Officer

Name

Designation

Handwritten signature and date: 9/1/15