

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110 001

Fax:-011-23412593

E-mail ID: cfhq.dlfire@nic.in

No. F.6/DFS/MS/GH/2015/ND2/148

Dated: 02/02/15

FIRE SAFETY CERTIFICATE

Certified that the **Hotel Blue Sapphire** located at **3351-54, Christen Colony, Bank Street, Karol Bagh, New Delhi-110005** comprises of Basement, Ground floor + Four Upper floors, using basement as hall, Ground floor as reception, office, hall, shops and staff pantry, first floor having nine guest rooms and one store room, second floor having five guest rooms and one store room, third floor having nine guest rooms and one store room (**Total 23 guest rooms**) and one staff room on terrace was granted NOC by this department vide letter No.F.6/DFS/MS/GH/2012/135 dated 13-01-2012. The premises was re- inspected by the officer concerned of this department on 24-01-2015 in the presence of Mr. Manjeet Singh and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, Sub-Division A-1 Guest House** for 23 guest rooms with effect from ~~02/02~~ 2015 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....02/02/15.....at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph-011-23414333

Copy to:-

1. The Joint Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi-110049 w.r.t. letter No. 547/Joint C.P./Lic.(H) dated New Delhi 07-01-2015.
2. Mr. Suman Anand (Owner) Hotel Blue Sapphire, 3351-54, Christen Colony, Bank Street, Karol Bagh, New Delhi-110005.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry"

INSPECTION REPORT

1. Name & address of the building : Hotel Blue Sapphire, 3351-54, Christen Colony, Bank Street, Karol Bagh, New Delhi-110005.
2. Type of Occupancy : Residential (Guest House) B+G+4 Floor total guest rooms-23
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/GH/2012/135 dated 13/01/2012
5. Fire Safety directives letter No : N/A
6. Date of inspection : 24/01/2015
7. Name of Inspecting Officer : Dy. C.F.O Rajesh Panwar
8. Name and designation of officers
From the building side : Sh. Manjeet Singh
9. Year of Construction : Before 2002
10. Applicant's letter No. : 547/Joint C.P/Lic (H) dt New Delhi 07/01/2015

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC/BBL Requirement | Provided at site special area | Remarks MR/NMR |
|--------|---|---|--|------------------------------|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | Accessible NA NA | 12 mtr NA NA | MR NA NA |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floors • Basements | One One | One One | MR MR |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floor • Basements | 125 cms 125 cms | 107 cms to 119 cms 114 cms | MR, Old Case MR, Old Case |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> • Fire check door • Pressurization | NA NA | NA NA | NA NA |
| | d. No. of continuous staircases to terrace | | | |
| | | One | One | MR |
| | e. Width of Corridor | 1.0 Mtr | 2.0 Mtr | MR |
| | f. Door Size | 1.0 Mtr. | 87cm X 204 cm | MR, Old Case |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | NA NA NA NA NA | NA NA NA NA NA | NA NA NA NA NA |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> • Basements • Upper floors | 30 ACPH 12 ACPH | Exhaust Fans are provided Natural Ventilation | MR MR |
| | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers • Types • IS marking | Two at each floor Co2, Water Co2 ISI marked | Provided Provided ISI marked | MR MR MR |
| | First-Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter | One 30 m 5 mm | Provided Provided Provided | MR MR MR |


| | | | | |
|-----|--|---|---|--|
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power | NA NA NA Required NA | NA NA NA D.G set of 45 KVA NA | NA NA NA MR NA |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | Required | Provided | MR |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling | Required NA NA | Provided NA NA | MR NA NA |
| 11. | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | NA NA NA | NA NA NA | NA NA NA |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | NA NA | NA NA | NA NA |
| 13. | Pumping Arrangements | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump | NA NA NA NA NA NA NA NA NA 450 LPM 30 M Required NA | NA NA NA NA NA NA NA NA NA 450 LPM 30 M Provided NA | NA NA NA NA NA NA NA NA NA MR, Old Case MR MR NA |
| 14. | Captive Water Storage for fire fighting | | | |
| | <ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity | NA NA NA NA 5000 Ltr Required | NA NA Provided NA 5000 Ltr Provided | NA NA MR NA MR, Old MR |
| 15. | Exit Signage. | | | |
| 16. | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage | NA NA Required Required Required | NA NA Provided Provided Provided | NA NA NA NA NA |

| | | | | |
|-----|--|----------|----------|----|
| 17. | Standby power supply | Required | Provided | MR |
| 18. | Refuge Area. | | | |
| | ➤ Total Area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire Control Room | | | |
| | • Detector System Panel | NA | NA | NA |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Batter backup | Required | Provided | MR |
| | • Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | NA | NA | NA |

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/GH/2012/135 dated 13.01.2012 renewal under rule 35 of Delhi Fire Service Rules 2010, is recommended please.

Signature of Inspecting Officer


28/11

Name:- Rajesh Panwar

Designation:- Dy. C.F.O (NDZ)

Signature of Inspecting Officer

Name

Designation

